



**GPU Nuclear Corporation**  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:

September 9, 1983  
5211-83-243

Office of Nuclear Reactor Regulation  
Attn: J. F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Sir:

Three Mile Island Nuclear Station, Unit (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Relief and Safety Valve Testing (NUREG 0737, II.D.1)

In response to your letter of July 5, 1983 and as discussed between members of your Staff and mine on July 26, 1983, enclosed please find our response to your questions. Additionally, RELAP V analysis for the 400°F subcooled water condition were transmitted to EG&G Idaho on August 5, 1983.

Sincerely,

*H. D. Hukill*  
H. D. Hukill  
Vice President - TMI-1

cc: R. Conte  
J. Van Vliet

*Aug 11  
Printed  
Dist*

8309160114 830909  
PDR ADOCK 05000289  
P PDR

RESPONSE TO NRC LETTER  
DATED JULY 5, 1983

RELIEF AND SAFETY VALVE TESTING



Item 1. Selection of "feed and bleed" as the transient that would produce the maximum loads on the discharge piping could not be verified since no discussion of the methods or details of analyses are included in the submittal. The submittal cites the Electric Power Research Institute (EPRI) report, "Valve Inlet Fluid Conditions for Pressurizer Safety and Relief Valves for B&W 177-FA and 205-FA Plants", as justification for the selection. The cited report does not describe a transient titled "feed and bleed". The conditions identified in the submittal, subcooled water at 400°F and 2500 psig, appear to be those resulting from extended high pressure injection events. A discussion should be provided describing the methods used to select the limiting transient and clarifying the events of the transient.

Response:

The term feed and bleed (also referred to as extended HPI) is discussed in section 4.4 of the "Valve Inlet Fluid Conditions for Pressurizer Safety and Relief Valves for B&W 177 and 205 FA Plants". In this report, 3 specific limiting cases are discussed.

Case 1 - High temperature water SB LOCA less than 0.02 ft.<sup>2</sup>

In this case the energy discharged through the break is not sufficient to remove core heat. No main or emergency feedwater is assumed available to sustain natural circulation on the primary side. Heat removal is accomplished by high pressure injection into the primary with discharge through the pressurizer safety/relief valves.

Case 2 - Low Temperature Water - Steam Line Break

In this case the overcooling event is intensified by using minimum core decay heat, large uncontrolled emergency feedwater flow, and no operator action to throttle or stop HPI. A minimum of 400°F subcooled water discharge resulting from the analyses was performed in response to IE Bulletin 79-05A&B.

Case 3 - Steam - Startup Rod Withdrawal

The design basis event for TMI-1 with a steam discharge is the startup rod withdrawal accident (See FSAR Section 14.1.2.2). The transient is terminated by the high pressure trip.

The report on valve inlet fluid conditions also set the limit for pressurizer surge line flow rate. As it shall be presented in the response to Item 8 in detail, the TMI-1 plant specific maximum surge line in-flow is much less than the set limit, and the corresponding EPRI test has resulted in a safety valve flow rate much greater than that the TMI unit would generate. Since only one safety valve is assumed open at a time, then the surge line in-flow is

conservatively equated to safety valve discharge flow. This leads to the conclusion that both the fluid conditions and the test results are applicable to TMI-1.

Item 2. The submittal does not include a discussion of consideration of single failures after the initiating events. NUREG-0737 required selection of single failures that produce maximum loads on the safety valves. A discussion should be provided describing how the single failure considerations required by NUREG-0737 are met.

Response:

As described in the response to item 1, the bounding cases are a high and low temperature water condition.

The single failure, for the purposes of this analysis, for the high temperature water case is an assumed loss of emergency feedwater which necessitates extended HPI operation (Feed and Bleed).

The single failure, for the purposes of this analysis, for the low temperature water case is no operator action to throttle HPI during the overcooling event (additionally, EFW Flow is also considered uncontrolled).

The single failure, for the purposes of this analysis, for the steam case is no pressurizer spray capability in the pressurizer.

All other license basis events result in lower loads on the safety/relief valves and discharge piping.

Item 3. Overpressure transients will cause the pressurizer sprays to activate adding moisture to the steam volume. When the safety valves lift or the power operated relief valves (PORVs) are opened they would be passing a steam-water mixture. Was this effect considered in the analyses done to select the transients that produced maximum loads on the discharge piping?

Response:

The analyses performed on the safety/relief valves indicate that steam/water exist in the valve and down stream piping resulting from flashing of water or condensation of steam. A specific steam-water analysis was not performed. However, a steam analysis (Attachment 3) and a water analysis (Attachment 1) were performed which indicate maximum loads occur for water discharge.

The purpose of the B&W report is to document the expected range of fluid inlet conditions to which the PORV and SRV's may be subjected. The B&W report does not evaluate two phase inlet conditions.

Discharge piping design input assumptions such as: a) lower than expected inlet water temperature, b) higher than rated valve flow rate (see response to

item no. 7), and c) fast opening time (see response to item no. 16), are deemed sufficient to insure conservatism in the analysis.

Item 4: The evaluation by Babcock and Wilcox (B&W) that showed up to 20% blowdown can be tolerated without any adverse effect on safety could not be verified since details of the analyses were not provided. The evaluation was based on hot leg voiding but no discussion was included to demonstrate that it is the limiting criteria. The increased blowdown would also cause a higher rise in the pressurizer level during transients that result in the safety valves lifting. No discussion is provided to demonstrate the level will not reach the discharge piping connection resulting in a transition of flow through the safety valves from steam to water-steam mixture. Details of the analyses supporting the conclusion that there will be no adverse effect on safety and details of the analyses demonstrating that the water level will not reach the discharge piping should be provided.

Response:

Attached, please find a copy of the "Pressurizer Safety Valve Maximum Allowable Blowdown" (Attachment 2), which discusses the details of the analysis.

Hot leg voiding has been identified as the primary safety concern relative to the maximum allowable PSV blowdown. The potential for hot leg voiding exists because of the lower system pressure that will be caused by larger PSV blowdown values. These lower pressures combined with transients that produce high system temperatures could result in saturation conditions and voiding that could impede natural circulation cooling.

This increase in pressurizer safety valve blowdown is not a direct safety concern. All nuclear plants are designed to accommodate Loss of Coolant Accidents including that which would result if a pressurizer safety valve sticks in the open position - i.e., an unlimited (100%) blowdown.

An additional desirable criteria would be that the pressurizer not fill for the larger PSV blowdown values. The pressurizer has a greater potential for filling because the larger blowdown values will allow large insurges during the blowdown cycle. The same EPRI tests that identified the blowdown concern also showed the safety valves were generally able to relieve two-phase fluid and water; thus, filling the pressurizer is a concern of secondary importance.

Item 5. The B&W Report on "Valve Inlet Fluid Conditions for Pressurizer Safety and Relief Valves" does not include the consequences of a reactor coolant pump shaft seizure, which is the accident which, in some plants, results in the fastest increase in and the highest peak reactor coolant system pressure. Why wasn't this considered in determining the worst case transient?

Response:

Section 14.1.2.6.3 of the TMI-1 FSAR addresses the locked rotor transient which results in a flux-flow trip. The B&W design mitigates the consequences of the accident which yields high pressures in the Westinghouse design. Attachment 2, Table 2 indicates high pressure and temperature events for B&W reactors. The "Valve Inlet Fluid Conditions for Pressurizer Safety Valves and Relief Valves for B&W 177 and 205 FA Plan B" did not include this transient since it potentially does not challenge the PORV or safety valves (15 psig above nominal).

Item 6. The submittal states that the ring settings to be used for the safety valves are those that showed the most stable valve configuration during the Electric Power Research Institute (EPRI) testing. The specific ring settings, however, are not identified. The back pressures for steam flow are given in the submittal but the back pressures for flows with subcooled water at the valve inlet are not provided. The submittal does not discuss the test valve performance to verify that the valve did perform satisfactorily. The specific ring settings to be used should be provided. A comparison should be provided that demonstrates, with the specified ring settings and appropriate back pressures, the valves will have stable operation for the Final Safety Analysis (FSAR) transients, will pass rated steam flow and will pass adequate flow to protect the primary system from over pressure for transients with subcooled water at the valve inlet.

Response:

By GPUN letter dated October 28, 1982 (82-260), GPUN informed NRC that the safety valves had been adjusted to the EPRI ring settings.

The TMI-1 plant specific ring settings are as follows:

Lower Ring	+11 notches
Middle Ring	-40 notches
Upper Ring	-48 notches

The EPRI test parameters were established to envelope the B&W, CE and Westinghouse transient conditions by using the most severe transients. Backpressures were established by EPRI using the maximum allowable backpressures per valve manufacturer requirements. A valve that operates satisfactorily at the most severe test conditions will meet plant conditions which are less severe. The TMI-1 conditions are bounded by the EPRI test conditions.

The valve ring settings are based on satisfactory performance on steam transients because the valve was designed for steam. Therefore, the ring settings for steam have to be the ring settings for water. See answer to question 8 for discussion of valve performance with subcooled water.

Item 7. The submittal describes the safety valves as Dresser Valves Model 31739A with a rated relief capacity of 317,973 lb/hr. However, the same model valve used in the EPRI test program is identified in the EPRI test report with a rated relief capacity of 297,845 lb/hr. The apparent difference in rated flow should be explained.

Response:

See second note on bottom of Table 1 of revision 1 of Gilbert report (Attachment 1) for a discussion of flow rates. Dresser Valve Model 31739A has only one orifice size which is 2.545 in.<sup>2</sup>. Therefore, the only variable in the capacity equation ( $W=51.5KAP$ ) is the inlet pressure. The higher the inlet pressure, the higher the flow.

W = capacity in lb/hr

K = constant = .8775 = .9 x .975

A = orifice area = 2.545

P = pressure = 2500 psig + accumulation + 14.7 psig

W =  $51.5 \times .8775 \times 2.545 \times (2500 + .03 \times 2500 + 14.7) = 297,846 \text{ lb/hr.}$

W =  $51.5 \times .8775 \times 2.545 \times (2500 + .1 \times 2500 + 14.7) = 317,973 \text{ lb/hr.}$

The higher flow rate was used for conservatism in the analysis of the discharge piping.

Item 8. The EPRI test series for the Dresser Valve Model 31739A included a test at 400°F subcooled liquid in which the valve only partially opened. The system pressure continued to accumulate and the test was terminated. The test considerations nearly duplicated the conditions for the subcooled transient selected in the submittal. Verifications should be provided to demonstrate that the valve will provide sufficient flow to relieve the pressure for the selected transient.

Response:

Under the EPRI proposed bounding conditions, namely, extended operation of three large HPI pumps (620 gpm @ 2500 psig) and maximum (1.2 times ANS) decay heat, assuming the valve inlet temperature to be 579°F, initially, the valve inlet temperature and surge line flow are calculated to be:

<u>Time</u>	<u>Temperature (°F)</u>	<u>Flow (lbm/hr)</u>
0	579.0	227,000
1 hr.	530.0	240,000
2 hrs.	470.1	255,000
3 hrs.	433.5	264,000

Under the realistic conditions of TMI-1, i.e., 2 HPI pumps (480 gpm @ 2500 psig) and 1.0 ANS decay heat, the fluid conditions are:



<u>Time</u>	<u>Temperature (°F)</u>	<u>Flow (lbm/hr)</u>
0	579.0	174,000
1 hr.	547.5	182,000
2 hrs.	496.9	192,000
3 hrs.	463.5	200,000

The EPRI water tests at 550°F and 400°F (tests 1112 and 1114) resulted in maximum flow rates of 450,000 lbm/hr and 500,000 lbm/hr, respectively. Although in the latter case, the system pressure continued to accumulate and the test was aborted at 2750 psia, the valve open flow rate exceeds that calculated for both realistic and bounding cases for TMI-1, and thus should be considered acceptable.

Review of the B&W Valve Inlet Fluid Conditions reveals that in the determination of the surge flow, B&W has incorporated conservatism by taking the sum of two terms: one for HPI injection and one for thermal expansion. Actually, as cold HPI water is mixed with hot RCS water, a contraction is resulted that reduces the net expansion owing to core decay heat.

Item 9. The submittal lists the TMI-1 power operated relief valve (PORV) as a model 31533VX-30 with a 1-3/32 in. bore. The PORV tested by EPRI was a Dresser Model 31533VX-30-2 with a bore diameter of 2-5/16 in. The effect on performance resulting from the difference in models and bore diameter should be addressed.

Response:

The EPRI Valve Selection/Justification Report discusses the differences between the various Dresser Valve models and the differences in bore diameters. The TMI-1 valves have been modified to have the -2 internals and therefore, there is no difference in operation between the TMI-1 valve and the EPRI valve. Both valves have the same size internals. The only difference between the valves is in bore diameter and this affects capacity only and that only in a minor way. The valve functions as a result of pressure ratios based on seat diameter and both valves have the same seat size (1-5/16").

Item 10. The Dresser PORV tested by EPRI failed to close and had a delayed closure for the test conditions of low temperature water followed by 550°F water. Verification should be provided to demonstrate that this performance of the valve will not have an adverse effect on the safety of the plant.

Response:

These tests were for a cold loop seal discharge followed by hot pressurizer water. This test is for plants which have a loop seal before the PORV. TMI-1 does not have a loop seal before its PORV. Therefore, this test is not applicable to TMI-1.

Item 11. NUREG 0737 requires qualification of the block valve. Specific data demonstrating qualification of the block valve is not given in the submittal. A reference is made to a report by R. C. Youndahl indicating satisfactory performance for a similar valve. The TMI-1 block valve is identified as a Velan 2-1/2 inch gate valve F9-454B-13MS with Limitorque operator SMS-00-10. The valve tested in the EPRI program was a Velan Valve, B10-30548-13MS. The EPRI tests demonstrated closure only with steam. Additional information should be provided to verify that the test valve adequately represents the TMI-1 valve and the testing with steam only provides adequate assurance that the valve will open and close satisfactory for the required plant conditions.

Response:

TMI-1 Block Valve F9-454B-13MS  
EPRI Test Block Valve B10-30548-13MS

F = flanged end	B = Butt weld ends	)No affect on representation
9 = 2-1/2"	10 = 3"	)due to similarity of valve
4 = 2500 lb rating	3 = 1500lb rating	)internals & operation
5 & 05 = conventional port gate valve, OS&Y		)
4B - vertical stem, bolted bonnet		)
13 - 316 stainless steel body		)Same for both valves
MS = 316 stellited disc & seat, 630 stem		)

The TMI-1 valve and the EPRI test valve are the same Type Velan valve (style, internal design, operation) except for size, pressure rating and valve ends which have no effect on valve operation.

The valve motor operator sizing equations use pressure to determine required operator torque outputs. The fluid and/or flow rate are not used in the sizing equations. Therefore, an operator sized to close a valve against a 250 psi pressure differential will operate on either steam or water flow.

Two Velan valves were tested during the EPRI test, both with the same model number. One was an older version of the valve and is similar to the TMI valves. The other is a newer version and is also similar to the TMI valves with regard to internals and operation. The older valve has an SB-00-15 operator and the new valve has an SMB-000-10 operator. Both valves operated satisfactorily during the testing. The older valve started with a torque switch setting of 1.7 (155ft-lbs). Supplemental tests were run down to a torque switch setting of 1.0 (82 ft-lbs). The new valve started with a torque switch setting of 1.5 (110ft-lbs). The supplemental tests were run down to a torque switch setting of 1.0 (82ft-lbs). During the tests the inlet pressures during flow were approximately 2300 psig - 2400 psig with flows of approximately 235,000 lb/hr. (The older valve's operator was originally procured for a 12" gate valve per Limitorque). There was minor seat leakage at the lowest torque switch setting, but did not affect valve operation.

The TMI-1 valve originally had a torque switch setting of 1.5 - 2.0 (60ft-lbs to 75ft-lbs). The setting was revised in 1981 to 2.75 (98ft-lbs). This revision was due to a review of the torque switch setting based on the EPRI test data and using a 2750-psi delta P. The required output torque was calculated in the same manner as the output torque calculated for the EPRI test valves. The reason why the EPRI test valves have a higher torque is because the EPRI valves are 3 in. valves. The area term of the differential pressure component is the reason for the increased required torque in the EPRI valves. Based on the Limitorque method of calculating, the TMI-1 torque switch setting is consistent with the EPRI test data.

The Limitorque method of calculating required output torque uses the differential pressure to determine the required total stem thrust. The type of fluid causing the differential pressure is not of a concern. Only the differential pressure is important.

The EPRI valves were tested in the horizontal position and the TMI-1 valve is installed in the vertical position. The difference in orientation does not affect the test results or the application of the test results to TMI-1. The valves are designed for both orientations. Also the Limitorque sizing calculation does not require the orientation. The valve disc is guided in the valve body so that internal valve forces do not affect valve operation or required stem thrust. Therefore, operator sizing is the same for both vertical and horizontal orientation.

The TMI-2 block valve is a Velan Model F9-354B-13MS, the TMI-1 valve is a Velan Model F9-454B-13MS. The only difference is that the TMI-2 valve is rated at 1500 lbs and the TMI-1 valve is rated at 2500 lbs. Both valves have the same size motor operator, SMB-00-10. Although the TMI-2 torque switch setting cannot be verified, it is assumed that it is the same as the original TMI-1 torque switch setting. This assumption is based on the fact that the TMI-1 valve was originally procured for TMI-2 and the TMI-2 valve was purchased as a direct replacement for the original valve. The valve installed in TMI-2 did operate satisfactorily during the March 29, 1979 incident. The torque switch setting is assumed to be approximately 1.5 - 2.0 (output torque of 60ft-lbs to 75ft-lbs).

Item 12. Describe what steps are being taken to remedy the recent corrosion observed on the TMI-1 PORV which has been attributed to excessively corrosive reactor coolant water. Are the valves being modified in any way to help eliminate this problem? It is our understanding that the loop seal in the safety valve inlet piping has been eliminated. Will this aggravate the corrosion of the safety valves since the valves will now be in direct contact with the pressurizer steam?

Response:

Recent corrosion problems associated with the PORV reported on March 7, 1983 (LER 83-003) and the remedy was subsequently discussed in Rev. 1 to that LER dated June 6, 1983. By eliminating the residual sulfur in the RCS through



cleaning ( $H_2O_2$ ) and hydrolazing, deletion of the sodium thiosulfate tank, refurbishment of the valve, frequent chemical monitoring, and valve inspection further corrosion is expected to be minimized. The safety and relief valves are not being modified as a result of this problem. The advantage of the loop seal was to reduce  $H_2$  cutting of the valve seats. Experience at similar plants has shown this effect to be very minor.

Item 13. The submittal describes the intended modifications to mount the safety valves and the PORV on the pressurizer nozzles. This modification would significantly affect the loads on the pressurizer nozzle. The submittal does not discuss the effect of the modification and the effect of the valve discharge loads on the ASME Section III, Class 1 analysis of the pressurizer nozzles. Verification that the Section III, Class 1 stress limits are met should be provided.

Response:

The original design of the B&W NSSS provided for safety valves to be mounted directly on the pressurizer nozzle. During the construction phase, Met Ed decided to move the valves to the end of the loop seal and provided a justification for that new design. GPUN, as a result of the EPRI test results, has returned the system to its original configuration.

Item 14. The submittal states that the safety valves and PORV connections to the pressurizer are assumed as anchors. It does not mention the large displacement of the connection due to the thermal expansion of the pressurizer when heated to operating conditions. Verification should be provided that the displacement were considered in the stress analyses of the piping and pressurizer nozzles.

Response:

Pressurizer nozzle thermal growths were accounted for by using anchor movement inputs in thermal analysis (for example, vertical thermal displacement = 1.375"). Thermal movement calculations are included in Attachment 1, pp. 32-34.

Item 15. The submittal states that the valve nozzle loads at the outlet flanges imposed by the discharge piping exceeds the allowable listed in the vendor catalog for the safety valves and exceeds those shown in the previous design for the PORV. It states that the loads for both types of valves have been re-evaluated by Dresser, the vendor, and found to be acceptable. However, the acceptance criteria and details of the analyses are not given. Sufficient additional information should be provided so that the acceptability of the nozzle loads can be verified or appropriate references cited.

Response:

By letter dated November 11, 1982, GPUN was notified by Dresser Industries as to the acceptability of the loads at the outlet flanges: the loads were combined as follows:

Normal Operation	Deadweight # + Thermal Case #
Normal Operation (safe shutdown earthquake-valve closed)	Deadweight # + 2 x OBE Seismic + Thermal Case 3
Upset Operation (valve open)	Deadweight + Thermal + Blowdown
Upset Operation (safe shutdown earthquake-valve open)	Deadweight + Thermal + Blowdown + 2 x OBE Seismic

Nozzle load information is provided on page 55 of the revised Attachment 1.

Item 16. The submittal identifies the initial conditions and valve opening times for the safety valves and PORV analyses. However, the method of handling the valve resistances is not described and the corresponding flows are not reported. Since the ASME code requires derating the safety valves to 90% of predicted flow, actual flows of 100% of rates are likely. Additional information should be provided describing considerations of safety valve derating and describing methods used to predict the flows for the safety valves and the PORV.

Response:

The valve flow areas used in the RELAP-V models were chosen so as to produce a steady state steam flow of 370,968 lbm/hr @ 2500 psig for each SRV and 116,667 lbm/hr @ 2300 psig for the PORV. These values correspond to rated flow corrected for 10% ASME derating and a 5% error. These values conservatively maximize the discharge piping analysis.

The SRV opening times used were obtained from Tables 3.1.1.b and 3.1.1.c of the EPRI Safety Valve Test Data Report corresponding to the short inlet configuration. The shortest opening times reported are 0.012 sec. and 0.043 sec for steam and water conditions, respectively. Therefore, the SRV opening characteristic used in the RELAP5 analysis was linear opening at 0.012 and 0.040 sec, respectively for the steam and water cases.

Item 17. Two valve opening sequences were considered in the submittal, the two safety valves opening simultaneously and discharging without PORV flow and the PORV discharging by itself. These sequences however, may not bound the forces for all possible valve opening

sequences. The experience of EG&G Idaho indicates that maximum forces would be expected when the sequence of opening is such that the initial pressure waves from the safety valves opening reach the common junction, located 1-1/2 ft above the drain tank, simultaneously. The safety valve lines and the PORV line were apparently modeled independently; however, if the PORV is discharging with flow past the junction when the safety valves open, piping loads may be significantly affected. Additional justification should be provided to demonstrate that the sequences considered in the submittal are adequate.

Response:

The sequences used for the SRV's and PORV are conservative for discharge piping transient analysis and provide bounding loads.

(a) SRV Sequencing:

Both SRV-A and SRV-B are conservatively assumed to actuate simultaneously. The design basis loading on the SRV discharge piping is based on the 400°F subcooled water discharge case. Despite having a larger force magnitude, the initial wave spike is not the controlling load. The fluid momentum results in a later and broader peak on the discharge piping which piping analysis has determined to be the controlling case. These force time history profiles may be seen by reviewing Attachment 1 of our submittal.

The length of piping between the SRV's and the common junction is approximately 125 ft. The length of SRV-A discharge piping is approximately 6 ft. longer than that of SRV-B. Further information concerning the fluid condition within the SRV discharge lines and their common junction can be obtained by reviewing the RELAP5 computer run for 400°F subcooled water discharge included herein. Items such as nodal pressure within the discharge lines may be seen by studying the provided nodal pressure for components 7 and 17 for each RELAP5 major edit output. RELAP5 minor edit output also provides information concerning individual pipe segment forces and flow rates from the valves, to the common junction, and from the common junction in 1 millisecond intervals.

(b) PORV - SRV Sequencing:

The PORV discharge piping analysis was done separately. The resulting steady state backpressure at the common junction is 73 psia. Therefore, using a backpressure of 70 psia (RCDT rupture disc pressure rating) adequately models the SRV analysis backpressure.

Conclusion: Based on the above, the conservative flow rates, and opening times used in the analysis, the SRV/PORV discharge piping hydraulic loading functions used are conservative.

Item 18. The adequacy of the thermal-hydraulic analyses could not be verified since sufficient detail is not provided in the submittal. To provide for a more complete evaluation, additional discussion should be provided for the rationale used in the selecting key parameters such as node spacing, time steps, valve flow area and choked flow junctions. Computer printouts of input and output for key problems should also be provided. Suggested key problems are the RELAP5 printouts for the 400°F subcooled water case for both the safety valves and the PORV.

Response:

Calculations and computer output are available for inspection at GPUN or the contractors facilities. A copy of RELAP V analysis for 400° subcooled water was transmitted to EG&G Idaho, August 5, 1983. In addition, the following general criteria were used in developing the RELAP V models:

(a) Nodal Spacing

Near the valve outlet the node size is initially restricted by the geometry of the pipe segment and are typically 0.5 ft. As downstream segments become longer, node length was sometimes increased but the volume change was always less than 50% for adjacent nodes.

Our contractors' experience (See Appendix A of our previous submittal) and sensitivity studies described in EPRI/CE Reference 1 of our previous submittal indicate this criteria is sufficient in modelling relief valve discharge transients.

(b) Time Step Size

The maximum time steps were evaluated using the Courant limit.

$$t = \frac{X}{V+C}$$

where: t = maximum time step

X = minimum nodal length

V = maximum phasic velocity

C = speed of sound

In addition, the minimum time step used was  $1 \times 10^{-10}$  seconds.

The maximum time step used was  $1.0 \times 10^{-4}$  sec.

(c) Valve Flow Rates

Valve flow rates are addressed in response to 16 above.

(d) Choking

RELAP V junctions were allowed to choke at all area changes.

Item 19. Solving the acceleration term of the momentum balance equation was used to develop a forcing function for the structural code. The experience of EG&G Idaho with this technique is that spurious data spikes will occur during water discharge transients if every RELAP V computational time step is used. However, if a finite time step is used the technique may not include the peak load. A discussion of the solution techniques should be provided which demonstrates the accuracy and applicability of results for water discharge transients.

Response:

The forcing functions for the structural code were calculated by solving the acceleration term of the momentum balance equation by using every RELAP V computational time step. Although this technique sometimes results in spurious force data spikes, this is not the case for most of the forces calculated. See Appendix B (Attachment 1) for force time histories for every RELAP V computation time step. No smoothing out was performed on the curves.

Item 20. Insufficient information is available to assess the structural analyses. A more complete assessment requires description to be key parameters used in the analyses such as damping, lumped mass spacing details of support models, and the integration time step.

The submittal infers that only the net unbalanced forces for the RELAP elements were used as input to the structural analysis. A discussion should be provided that describes how the axial extension from the balancing forces on each end of the elements was treated. Computer printouts of input and output for key problems should be provided. Suggested key problems are the TPIPE printouts for the 400°F subcooled water case for the safety valves lifting simultaneously and for the PORV lifting along.

Response:

The following parameters were used in the analyses.

(a) Damping Ratio = 0

How is zero damping applied?

In the direct integration method of TPIPE, the damping matrix C used is computed by

$$C = \alpha M + \beta K$$

Where  $M$  is the mass matrix,  $K$  is the stiffness matrix. The  $\alpha$  and  $\beta$  are arbitrary proportional factors. The damping ratio is specified by specifying  $\alpha$  and  $\beta$  in the TPIPE time history analysis inputs. Zero damping is applied by specifying  $\alpha = \beta = 0$  in TPIPE inputs.

This method is derived from Eq. (13 - 24) in Dynamics of Structures, by R. W. Clough & J. Penzien, McGraw-Hill, 1975.

No damping factor was used in the dynamic analysis.

(b) Lump Mass Spacing

Lumped masses were calculated for each nodal point by TPIPE Computer Code internally. Analysis node spacings can be found from the isometric drawings to the report.

(c) Modeling

The support eccentricity has been modelled. The details are available for inspection at GPU or Contractors' facilities.

(d) Integration Time Step

Analysis time step  $T = 0.001$  second was used in the TPIPE time history analysis for the blowdown load cases.

The forcing functions were checked between RELAP 5 result and TPIPE input to make sure that the analysis time step was acceptable and that the peak forces were accounted for.

(e) Axial Extension

The axial extension effect on piping stresses from the balancing forces on each end of the pipe elements were considered in the static pressure analysis by using peak pressure. This should cover the effects of transient pressure and momentum forces combined. Furthermore, the axial balanced forces have no effect on the support design.

(f) SRV lifting simultaneously

(See response to item 21.)

(g) Print-out of RELAP V for 400° subcooled water condition were transmitted to EG&G Idaho, August 5, 1983.

Item 21. The submittal indicates that the three piping branches were assumed to be structurally independent and that the connectors to the pressurizer and drain tank were treated as anchors. The interaction of the three branches at the junction 1-1/2 ft. above the drain tank and the flexibility of the connections would



appear to have a significant effect on the response and stress level of the piping. Additional justifications for these assumptions should be provided.

Response:

The three (3) piping branches were assumed to be structurally independent for the following reasons:

- (a) The interaction of the three (3) branch lines and the common header is isolated from the pressurizer connections by three (3) intermediate anchors, one on each branch.
- (b) The common junction is located in a relative stiff section of the piping adjacent to the pressurizer drain tank anchor.
- (c) The piping dynamic stress in the region of the common junction are very low (i.e., OBE stress 2000 psi and blowdown 1000 psi) leaving sufficient margins for the possible differences that may result from a more refined structural analysis model.

## APPENDIX B

RELAP5 MODELS AND DISCHARGE LINE  
PIPING FORCESSafety Valve Discharge Transients, RELAP 5 Models and Results

The safety valve discharge lines were modeled using a 233 volume and 233 junction RELAP5 model. Since the valve setpoints are both 2500 psig, the hydraulic forces on the discharge lines were evaluated assuming both safety valves open simultaneously. The generalized RELAP5 model is given in Figure B-1.1.


The hydraulic forcing functions are defined in Figure B-1.2 with the positive force direction defined opposite to the direction of flow. Figures B-1.3 through B-1.13 present the unbalanced forces along each straight segment of pipe for the 400°F subcooled water discharge transient.

Power Operated Relief Valve Discharge Transients, RELAP5 Model and Results

The PORV discharge line RELAP5 model contains 147 volumes and 146 junctions. The generalized RELAP5 model is given in Figure B-2.1.

The hydraulic forcing functions are defined in Figure B-2.2 with the positive force direction defined opposite to the direction of flow. Figures B-2.3 through B-2.10 present the unbalanced forces along each straight segment of pipe for the 400°F subcooled water discharge transient.





ⓧ COMPONENT NUMBER

THREE MILE ISLAND UNIT #1

RELAP MODEL FOR SRV LINES

FIGURE B-1.1




FIGURE B-1.2  
 THREE MILE ISLAND UNIT # 1  
 SAFETY VALVE RC-RV1A (ME-91.92)  
 DISCHARGE LINE  
 FORCES DEFINITION





FIGURE B-1.2A  
 THREE MILE ISLAND UNIT #1  
 SAFETY VALVE RC-RV1B (ME-88.89)  
 DISCHARGE LINE  
 FORCES DEFINITION

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

IMI-1 = PRESS. SRV ACTUATION = 400 F WATER 02/06/82



RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

IMI-1 = PRESS. SRV ACTUATION = 400 F WATER 02/06/82




FIG  
B-1.3





FIG.  
B-1.4





FIG  
 B-1.5





FIG  
 B-1.6







FIG  
 B-1.7









FIG  
 R-1.9





FIG  
B-1.10





FIG  
 B-1.11





FIG  
B-1.12





FIG  
 B-1.13





FIG  
B-1.14





FIG.  
 B-1.15







FIG  
B-1.16





FIG  
B-1.17





FIG  
B-1.18



THREE MILE ISLAND - UNIT #1  
RELAP MODEL FOR PORV LINE

FIGURE  
B-2.1




FIGURE B-2.2  
 THREE MILE ISLAND UNIT # 1  
 PORV RC-RV2 (ME-162.93)  
 DISCHARGE LINE  
 FORCES DEFINITION





FIG  
 B-2.3





FIG.  
 B-2.4







FIG.  
 B-2.5





FIG.  
 B-2.6





FIG.  
B-2.7





FIG.  
 B-2.8





FIG  
B-2.9




FIG.  
B-2.10

Appendix-C TPIPE Piping Analysis Report

METROPOLITAN EDISON COMPANY  
THREE MILE ISLAND NUCLEAR STATION  
UNIT-1

STRESS ANALYSIS OF PRESSURIZER  
SAFETY/RELIEF VALVE DISCHARGE PIPING

Originator : L. Chou

Reviewer : S. H. Yang

Supervisor : M. Z. Lee

SPECIALITY ENGINEERING DEPARTMENT  
GILBERT/COMMONWEALTH  
READING, PA

JULY, 1982



## ABSTRACT

The purpose of this report is to present the result of piping structural analysis of pressurizer safety/relief valve discharge line due to fluid transient, seismic, thermal and deadweight effects, also to demonstrate the evaluation of piping system in accordance with the guideline issued by EPRI, April 1982 ("Guide for application of valve test program results to plant specific evaluation", Appendix E.)

## TABLE OF CONTENTS

Section	Page
1. System Description -----	1
2. Analysis Description -----	2
3. Analysis Tool -----	4
4. Transient Conditions Analyzed -----	5
5. Loading Combination and Acceptance Criteria -----	6
6. Summary of Results and Conclusions -----	8
a. piping stress	
b. pipe support load	
c. nozzle load	
d. valve acceleration	
7. Design Input -----	13
8. Geometry Plots -----	35
9. Identification of Computer Output files -----	54
10. Evaluation of Pipe Support and Nozzle Load -----	55
11. Reference -----	56
12. Microfishe -----	Attachment

## 1. SYSTEM DESCRIPTION

Three Mile Island Nuclear Station, Unit-1 utilizes a Babcock & Wilcox pressurized water reactor system with an electric power output of 87½ MW.

Its primary loop overpressure protection system consists of two safety relief valves (SRV) and one power operated relief valve (PORV). Both SRVs and PORV are installed directly on the pressurizer, and consequently the valve connections at the pressurizer are assumed as anchors. The two 6", SRV discharge lines and the one 4" PORV discharge piping merge to a 10" common header, 1.5' above the reactor coolant drain tank.

## 2. ANALYSIS DESCRIPTION

The integrity of the piping system and its effects on the operability of the valves are analyzed for pressure, deadweight, seismic, thermal expansion, and the flow transient loads. The effects of the flow transient loads are analyzed in three steps: (1) perform thermal-fluid analysis to determine the states and the flow conditions of the fluid, (2) generate time dependent, flow induced forces on the pipe for piping dynamic analysis, (3) perform piping structural dynamic analysis. Steps (1) and (2) are performed by AEA - Dept. of Gilbert Associates, Inc. and are reported separately. This report covers step (3) and the analysis for pressure, deadweight, seismic and thermal expansion loadings. Fig. 2.1 shows the major analysis procedure.




Fig. 2.1 Analysis Functional Flow Diagram

### 3. Analysis Tool

Gilbert/Commonwealth piping analysis computer code TPIPE version 4.2, July 1982, was used in the piping system analysis. TPIPE is a general piping analysis computer code developed by PMB Systems Engineering, Inc. in San Francisco, and has been used by Tennessee Valley Authority, Gilbert/Commonwealth and other organizations for several nuclear power plant projects.

#### 4. Transient Conditions Analyzed

The SRV discharge piping could be subjected to saturated discharge and subcooled water discharge. Both cases were analyzed separately and the worse of the two loading cases for piping stresses and support loads were screened using TPIPE postprocessor.

The PORV discharge piping was analyzed for a 400F, 2500 psig subcooled water discharge.

5. Loading Combination and Acceptance Criteria

The loading combination and acceptance criteria for the SRV and PORV discharge systems were based on table 5.1, which were given in appendix E of reference 6.



LOAD COMBINATIONS AND ACCEPTANCE CRITERIA FOR PRESSURIZER SAFETY  
AND RELIEF VALVE PIPING AND SUPPORTS - SEISMICALLY DESIGNED DOWNSTREAM PORTION  
 (TABLE 5.1)

<u>Combination</u>	<u>Plant/System Operating Condition</u>	<u>Load Combination</u>	<u>Service Stress Limit</u>
1	Normal	N	A
2	Upset	N + SOT <sub>U</sub>	B
3	Upset	N + OBE + SOT <sub>U</sub>	C
4	Emergency	N + SOT <sub>E</sub>	C
5	Faulted	N + MS/FWPB or DBPB + SSE + SOT <sub>F</sub>	D
6	Faulted	N + LOCA + SSE + SOT <sub>F</sub>	D

DEFINITIONS OF LOAD ABBREVIATIONS

N	= Sustained Loads During Normal Plant Operation	SSE	= Safe Shutdown Earthquake
SOT	= System Operating Transient	MS/FWPB	= Main Steam or Feedwater Pipe Break
SOT <sub>U</sub>	= Relief Valve Discharge Transient <sup>(1)</sup>	DBPB	= Design Basis Pipe Break
SOT <sub>E</sub>	= Safety Valve Discharge Transient <sup>(1)</sup>	LOCA	= Loss of Coolant Accident
SOT <sub>F</sub>	= Max (SOT <sub>U</sub> ; SOT <sub>E</sub> ); or Transition Flow		
OBE	= Operating Basis Earthquake		

This table is applicable to the seismically designed portion of downstream non-Category I piping (and supports) necessary to isolate the Category I portion from the non-seismically designed piping response, and to assure acceptable valve loading on the discharge nozzle.

Use SRSS for combining dynamic load responses.

## 6. Summary of Results and Conclusions

6.1 The results of S/RV discharging piping are summarized as follows:

- a. PORV(ME-162,93) - Maximum stress in this piping branch is within allowable limits. (see table 6.1) Also, all snubber supports loads are within the designed capacities.
- b. SRV(ME-88,89) - Maximum stress in this piping branch just reached the allowable limits. (see table 6.2) All snubber supports load are within designed capacities.
- c. SRV(ME-91,92) -Maximum stress in this piping branch will be within allowable limits after adding one 3 kip snubber at joint 346 in Z direction. However, all the snubber supports load are still within designed capacities.
- d. The SRV nozzle loads at outlet flange imposed by the piping exceed recommended maximum loads shown on vendor . catalog (see Reference 1 or attached).
- e. The PORV nozzle allowable limits are not available.
- f. The Reactor Coolant Drain Tank (WDL-T-3) nozzle loads are below the allowable limits used for previous analysis.
- g. The normal operating condition for the S/RV discharging piping is when the SRV and PORV are closed. The discharging piping temperature will be the same as the plant normal enviromental temperature. The discharging piping will not contain any sub-cooled water during the system normal operating condition.



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT				CISID		PAGE
REV.	0	1	2	3	OF	
MICROFILMED						PAGES
ORIGINATOR <i>L. K. ...</i>						
DATE <i>7/20/87</i>						

Table 6.1 -- Stress Summary Of PORV Branch Piping (ME-162,93)

TRIBE TRI PUR SPRU DISCHARGE PIPING (ME-162,93) (U.O.#045064000) LLCMOG FROM PORV (RC-NV2) TO PRESSURIZER RELIEF TANK

ASME CODE CLASS 2 STRESS SUMMARY

MEMBER NAME	MODAL NAME	EQN NO.	CODE STRESS	ALLOWABLE STRESS	STRESS RATIO	DESCRIPTION
1500 X	146 X	8	6159.	15500.	.40	MAX STRESS
1500 X	146 X	8	6159.	15500.	.40	MAX STRESS RATIO
1270 X	CENTR X	10	24722.	27000.	.92	MAX STRESS
1270 X	CENTR X	10	24722.	27000.	.92	MAX STRESS RATIO
1270 X	CENTR X	11	27816.	42500.	.65	MAX STRESS
1270 X	CENTR X	11	27816.	42500.	.65	MAX STRESS RATIO
1510 X	148 X	9U	16762.	18600.	.90	MAX STRESS
1510 X	148 X	9U	16762.	18600.	.90	MAX STRESS RATIO
1510 X	148 X	9E	21122.	27900.	.76	MAX STRESS
1510 X	148 X	9E	21122.	27900.	.76	MAX STRESS RATIO
1510 X	148 X	9F	29788.	37200.	.80	MAX STRESS
1510 X	148 X	9F	29788.	37200.	.80	MAX STRESS RATIO
1270 X	CENTR X	PR	28678.	36480.	.79	MAX STRESS
1270 X	CENTR X	PR	28678.	36480.	.79	MAX STRESS RATIO
1510 X	148 X	AU	41608.	600000.	.07	MAX STRESS
1510 X	148 X	AU	41608.	600000.	.07	MAX STRESS RATIO

TOTAL NUMBER OF PIPE MEMBERS WITH MODAL POINTS GREATER THAN A THRESHOLD STRESS RATIO OF 1.000

EQUATION 8..... 0  
 EQUATION 10..... 0  
 EQUATION 11..... 0  
 EQUATION 9U..... 0  
 EQUATION 9E..... 0  
 EQUATION 9F..... 0

PIPE RUPTURE.... 0  
 ACTIVE VALVE.... 0



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				
ORIGINATOR <i>SKV</i>				
DATE <i>2/20/87</i>				

Table 6.2 -- Stress Summary Of SKV Branch Piping (ME-88,89)

PIPE THE PUM S/RU DISCHARGE PIPING (ME-88,89) (U.D.-845064000) LLCHOU FROM SRV(ME-147) TO PRESSURIZER RELIEF TANK ASSE CODE CLASS 2 STRESS SUMMARY

MEMBER NAME	NODAL NAME	EQN NO.	CODE STRESS	ALLOWABLE STRESS	STRESS RATIO	DESCRIPTION
2250 X	223 X	8	6061.	15500.	.39	MAX STRESS
2250 X	223 X	8	6061.	15500.	.39	MAX STRESS RATIO
2210 X	219 X	10	16087.	27000.	.60	MAX STRESS
2210 X	219 X	10	16087.	27000.	.60	MAX STRESS RATIO
2250 X	CENTR	11	21509.	42500.	.51	MAX STRESS
2250 X	CENTR	11	21509.	42500.	.51	MAX STRESS RATIO
2410 X	240 X	9U	18874.	18600.	.58	MAX STRESS
2410 X	240 X	9U	18874.	18600.	.58	MAX STRESS RATIO
2470 X	245 X	9E	20370.	27900.	.73	MAX STRESS
2470 X	245 X	9E	20370.	27900.	.73	MAX STRESS RATIO
2470 X	245 X	9F	37275.	37200.	1.00	MAX STRESS
2470 X	245 X	9F	37275.	37200.	1.00	MAX STRESS RATIO
2250 X	CENTR	PR	24390.	36400.	.67	MAX STRESS
2250 X	CENTR	PR	24390.	36400.	.67	MAX STRESS RATIO
2470 X	245 X	AU	38877.	603000.	.06	MAX STRESS
2470 X	245 X	AU	38877.	603000.	.06	MAX STRESS RATIO

TOTAL NUMBER OF PIPE MEMBERS WITH NODAL POINTS GREATER THAN A THRESHOLD STRESS RATIO OF 1.000

EQUATION 8..... 0  
 EQUATION 10..... 0  
 EQUATION 11..... 0  
 EQUATION 9U..... 0  
 EQUATION 9E..... 0  
 EQUATION 9F..... 1  
 PIPE RUPTURE.... 0  
 ACTIVE VALUE.... 0



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT

CISID

PAGE

REV.

0

1

2

3

MICROFILMED

ORIGINATOR

DATE

*J. K. ...*

7/26/82

OF

PAGES

MARK NO.	PIPE NODE NO.	SUPPORT LOAD (NEW/EXIST) LB				PERCENT CHANGE			
		NORMAL	UPSET	EMERGENCY	FAULTED	NORMAL	UPSET	EMERGENCY	FAULTED
PR46	103	NA	213/10350	244/10350	320/10350	NA	OK	OK	OK
PR50	S113		316/10350	339/10350	401/10350		OK	OK	OK
PR49	117		499/10350	506/10350	526/10350		OK	OK	OK
PR48	S133		1118/10350	1136/10350	1191/10350		OK	OK	OK
PR47	S138	↓	445/10350	537/10350	747/10350	↓	OK	OK	OK

TABLE 6.4 SNUBBER LOAD COMPARISON OF PORV (ME-162,93)



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT				CISID			PAGE
REV.	0	1	2	3	OF		
MICROFILMED					PAGES		
ORIGINATOR	D. K. ...						
DATE	7/26/82						

MARK NO.	PIPE NODE NO.	SUPPORT LOAD (NEW/EXIST) LB				PERCENT CHANGE			
		NORMAL	UPSET	EMERGENCY	FAULTED	NORMAL	UPSET	EMERGENCY	FAULTED
PR44	—	NA	—	—	—	NA	OK	OK	OK
PR43	S206		1525/25500	1525/25500	1570/25500		OK	OK	OK
PR41	211		2640/17600	2640/17600	2651/17600		OK	OK	OK
PR39	215		3805/17600	3805/17600	3964/17600		OK	OK	OK
PR37	S234		1658/25500	1658/25500	1801/25500		OK	OK	OK
PR26	237		2039/10350	2039/10350	2682/10350		OK	OK	OK
PR24	238		1424/17600	1424/17600	1443/17600		OK	OK	OK
PR35	242	↓	446/25500	446/25500	482/25500	↓	OK	OK	OK

TABLE 6.5 SNUBBER LOAD COMPARISON OF SRV (ME-88,89)





Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT

CISID

PAGE

REV.

0

1

2

3

OF

MICROFILMED

ORIGINATOR

*[Handwritten signature]*

DATE

*8/6/82*

PAGES

MARK NO.	TPIPE NODE NO.	SUPPORT LOAD (NEW/EXIST) LB				PERCENT CHANGE			
		NORMAL	UPSET	EMERGENCY	FAULTED	NORMAL	UPSET	EMERGENCY	FAULTED
PR45	S303	NA	<del>2308</del> /17600	<del>2308</del> /17600	<del>2442</del> /17600	NA	OK	OK	OK
PR42	308		<del>2286</del> /17600	<del>2286</del> /17600	<del>2356</del> /17600		OK	OK	OK
PR40	319		<del>3359</del> /17600	<del>3359</del> /17600	<del>3390</del> /17600		OK	OK	OK
PR38	319		<del>2627</del> /17600	<del>2627</del> /17600	<del>3978</del> /17600		OK	OK	OK
PR36	337		<del>3292</del> /5500	<del>3292</del> /5500	<del>6847</del> /5500		OK	OK	OK
PR25	340		<del>1731</del> /10350	<del>4447</del> /10350	<del>9676</del> /10350		OK	OK	OK
PR23	S341		<del>2422</del> /17600	<del>2422</del> /17600	<del>3348</del> /17600		OK	OK	OK
PR34	S345	▼	<del>3316</del> /27300	<del>3316</del> /27300	<del>3976</del> /27300	▼	OK	OK	OK
PRXX	346	NA	<del>469</del> /NA	<del>469</del> /NA	<del>841</del> /NA				

Note: SNUBBER PRXX IS PROPOSED

TABLE 6.6 SNUBBER LOAD COMPARISON OF SRV (ME-91, 92)



Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT

CISID

PAGE

REV.

0

1

2

3

OF

MICROFILMED

PAGES

ORIGINATOR

*W. J. ...*

DATE

*7/27/82*

MARK NO.	TPIPE NODE NO.	EXIST DESIGN LOAD (LB)	NEW LOAD (LB)	PERCENT CHANGE
PR22	107	-247	-227	OK
PR17	112	-67	-103	INCREASE 18%
PR14	116	-112	-137	INCREASE 22%
PR11	124	-197	-275	INCREASE 39%
PR5	137	-382	-471	INCREASE 23%

Note: ANALYSIS RESULT FROM JOB RUN I.D. AYXBCAU

TABLE 6.7 SPRING HANGER LOAD COMPARISON OF PORV (ME-162,93)





Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	J. K. HODGINS			
DATE	7/27/82			

MARK NO.	PIPE NODE NO.	EXIST DESIGN LOAD (LB)	NEW LOAD (LB)	PERCENT CHANGE
PR19	207	-169	-210	INCREASE 24%
PR16	210	-176	-199	INCREASE 13%
PR13	214	-245	-243	OK
PR10	222	-276	-544	INCREASE 97%
PR4	233	-451	-403	OK
PR1	241	-365	-425	INCREASE 16%

Note: ANALYSIS RESULT FROM JOB RUN I.D. AYXBCBD

TABLE 6.8 SPRING HANGER LOAD COMPARISON OF SRV (ME-88,89)



Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	S. K. P. M. A.			
DATE	7/27/82			

MARK NO.	TRPIPE NODE NO.	EXIST DESIGN LOAD (LB)	NEW LOAD (LB)	PERCENT CHANGE
PR20	307	-510	-696	INCREASE 36%
PR18	311	-218	-250	INCREASE 15%
PR15	314	-255	-335	INCREASE 17.5%
PR12	318	-380	-352	OK
PR3	336	-445	-417	OK
PR2	344	-371	-454	INCREASE 22%

Note: ANALYSIS RESULT FROM Job RUN I.D. AYXBCAV

TABLE 6.9 SPRING HANGER LOAD COMPARISON OF SRV (ME-91, 92)



Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT		CISID			PAGE
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR	JYF/OU				
DATE	7/27/82				

MARK NO.	TPIPE NODE NO.	EXIST DESIGN LOAD (LB)	NEW LOAD (LB)	REMARK
PR30 GUIDE	102	X $\begin{matrix} +144 & +470 \\ -329 & Z-522 \end{matrix}$	X $\begin{matrix} +210 & +256 \\ -358 & Z-337 \end{matrix}$	R
PR31 GUIDE	104	X $\begin{matrix} +2275 & +494 \\ -1029 & Z-776 \end{matrix}$	X $\begin{matrix} +1915 & +171 \\ -694 & Z-572 \end{matrix}$	OK
PR22 STRUT	107	$\begin{matrix} +920 \\ -2239 \end{matrix}$	$\begin{matrix} +696 \\ -2235 \end{matrix}$	OK
PR28 GUIDE	120	X $\begin{matrix} +440 & +1212 \\ -343 & Z-1793 \end{matrix}$	X $\begin{matrix} +714 & +639 \\ -125 & Z-1031 \end{matrix}$	R
PR27 GUIDE	121	X $\begin{matrix} +203 & +4767 \\ -2005 & Z-1276 \end{matrix}$	X $\begin{matrix} +209 & +3854 \\ -2397 & Z-377 \end{matrix}$	R
PR6A GUIDE	132	X $\begin{matrix} +225 & +570 \\ -177 & Z-921 \end{matrix}$	X $\begin{matrix} +412 & +908 \\ -242 & Z-298 \end{matrix}$	R
PR6 GUIDE	134	X $\begin{matrix} +230 & +1901 \\ -398 & Z-265 \end{matrix}$	X $\begin{matrix} +433 & +607 \\ -400 & Z-2330 \end{matrix}$	R

R : RE-EVALUATE NEEDED

TABLE 6.10 RIGID SUPPORT LOAD COMPARISON OF PORV (ME-162,93)



Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				PAGES
ORIGINATOR	E. J. ...			
DATE	7/27/82			

MARK NO.	TYPE NODE NO.	EXIST DESIGN LOAD (LB)	NEW LOAD (LB)	REMARK
PR29 GUIDE	200	X <sup>+362</sup> <sub>-982</sub> Z <sup>-791</sup> <sub>-367</sub>	X <sup>+29</sup> <sub>-510</sub> Z <sup>+292</sup> <sub>-154</sub>	OK
PR31 GUIDE	201	X <sup>+6074</sup> <sub>-2768</sub> Z <sup>100</sup> <sub>-457</sub>	X <sup>+4552</sup> <sub>-1439</sub> Z <sup>475</sup> <sub>-623</sub>	R
PR21 STRUT	204	+2446 -6192	+1647 -5941	OK
PR28 GUIDE	218	X <sup>+440</sup> <sub>-343</sub> Z <sup>+1212</sup> <sub>-1793</sub>	X <sup>+2382</sup> <sub>-1538</sub> Z <sup>7135</sup> <sub>-6685</sub>	R
PR27 GUIDE	219	X <sup>+203</sup> <sub>-2005</sub> Z <sup>+4767</sup> <sub>-1276</sub>	X <sup>+1246</sup> <sub>-5084</sub> Z <sup>8476</sup> <sub>-2091</sub>	R
PR4A STRUT	5230	±17000	+3732 -1789	OK
PR33 GUIDE	245	F <sub>x</sub> =+276 M <sub>x</sub> =+29709 -85 -28927 F <sub>y</sub> =+16478 M <sub>y</sub> =+5005 -16580 M <sub>z</sub> =+36414 -2511 -4158	F <sub>x</sub> =+583 M <sub>x</sub> =+24876 -194 -231305 F <sub>y</sub> =+2379 -1740	R

R : RE-EVALUATE NEEDED

TABLE G.11 RIGID SUPPORT LOAD COMPARISON OF SRV (ME-88,89)



Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				PAGES
ORIGINATOR <i>W. J. Conroy</i>				
DATE <i>7/28/82</i>				

MARK NO.	TPIPE NODE NO.	EXIST DESIGN LOAD (LB)	NEW LOAD (LB)	REMARK
PR29 GUIDE	302	X $\begin{matrix} +270 & +1295 \\ -654 & Z -267 \end{matrix}$	X $\begin{matrix} +1651 & +1989 \\ -2038 & Z -1416 \end{matrix}$	R
PR31 GUIDE	304	X $\begin{matrix} +4362 & +36 \\ -911 & Z -456 \end{matrix}$	X $\begin{matrix} +7688 & +1103 \\ -4324 & Z -1058 \end{matrix}$	R
PR20 STRUT	307	$\begin{matrix} +1214 \\ -3859 \end{matrix}$	$\begin{matrix} +4452 \\ -8643 \end{matrix}$	R
PR28 GUIDE	322	X $\begin{matrix} +440 & +1212 \\ -343 & Z -1793 \end{matrix}$	X $\begin{matrix} +2743 & +5404 \\ -1041 & Z -5134 \end{matrix}$	R
PR27 GUIDE	323	X $\begin{matrix} +203 & +4767 \\ -2005 & Z -1276 \end{matrix}$	X $\begin{matrix} +691 & +3876 \\ -8368 & Z -1569 \end{matrix}$	R
PR9 RIGID ROD	326	$\pm 5860$	$\begin{matrix} +4565 \\ -5346 \end{matrix}$	OK
PR3A STRUT	S332	$\begin{matrix} +16300 \\ -16800 \end{matrix}$	$\begin{matrix} +4528 \\ -1472 \end{matrix}$	OK
PR51 STRUT	333	$\begin{matrix} +265 \\ -253 \end{matrix}$	$\begin{matrix} +1677 \\ -2663 \end{matrix}$	R
PR32 GUIDE	348	$\begin{matrix} F_x = +235 & F_y = +16525 \\ -112 & -16781 \\ +29686 & +6175 \\ M_x = -30814 & M_y = -1861 \end{matrix}$	$\begin{matrix} F_x = +1864 & F_y = +2931 \\ -2085 & -2274 \\ +365604 & +41047 \\ M_x = -373920 & M_y = -51901 \end{matrix}$	R
		$\begin{matrix} M_z = +30877 \\ -6343 \end{matrix}$	$\begin{matrix} M_z = +64380 \\ -54744 \end{matrix}$	

\* NEW LOAD BASED ON EMERGENCY RESULTS

R : RE-EVALUATE NEEDED

TABLE G.12 RIGID SUPORT LOAD COMPARISON OF SRV (ME-91, 92)



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0430	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-4692	PAGE 43 of 44

SUBJECT: Support Load Summary Sheet

ORIGINATOR: D. SALLADE

MARK NO. PR-7

TYPE OF SUPPORT ANCHOR

ANALYSIS CODE ME-89

ANALYSIS JOINT NO. 108

NOTE: THESE LOADS ARE COMPLETE

DATE 6/20/80

VERIFIER J.M. GALWAY

DATE 7/28/80

ANALYSIS JOINT NO. 108

NOTE: THESE LOADS ARE COMPLETE

1

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	1(108)	-25	+42	+365	+194	+5185	-902
	2(1)	+1	+0	+7	+0	+0	+0
	3( )	-0	-28	-0	-75	-240	-1144
THERMAL	1(108)	+1877	+3032	+0	+0	+0	+0
	2(1)	-0	-0	-3622	-5765	-35854	-31899
	3( )	+0	+336	+50	+888	+0	+8304
SEISMIC - OBE	1(108)	±59	±307	±235	±1780	±3640	±5459
	2(1)	±86	±21	±62	±640	±2879	±537
	3( )						
DESIGN LOAD		+1998	+3650	+719	+3433	+11464	+12254
		-272	-374	-3547	-8072	-42540	-39941
HYPOTHETICAL LOAD		+2143	+3978	+1016	+5859	+17983	+18250
		-417	-702	-3844	-10498	-49059	-45937

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

Seismic Category	Loading Case	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal ± (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating



FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0430	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-4692	PAGE 41 of 44
SUBJECT Support Load Summary Sheet			ORIGINATOR D. SALLADE
MARK NO. <u>PR-8</u>			DATE <u>6/20/80</u>
TYPE OF SUPPORT <u>ANCHOR</u>			VERIFIER <u>G.P. BUROCK</u>
ANALYSIS CODE <u>ME-89,93,91 COMBINED</u>			DATE <u>7/23/80</u>
ANALYSIS JOINT NO. <u>38</u>			
NOTE: THESE LOADS ARE COMPLETE			

REV. 0

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		F <sub>X</sub>	F <sub>Y</sub>	F <sub>Z</sub>	M <sub>X</sub>	M <sub>Y</sub>	M <sub>Z</sub>
DEADWEIGHT	1(38)	+0	+0	+105	+3186	+2600	+5250
	2(1)	-69	-152	-0	-0	-0	-0
	3( )	+0	+0	+0	+7	+78	+0
THERMAL	1(38)	+1662	+416	+0	+0	+0	+0
	2(1)	-0	-0	-2333	-6708	-54644	-11336
	3( )	+64	+439	+50	+881	+0	+23009
SEISMIC - OBE	1(38)	±66	±30	±49	±406	±1080	±1054
	2(1)	±65	±9	±323	±1862	±23320	±224
	3( )						
DESIGN LOAD	1( )						
	2( )						
	3( )						
		+1743	+461	+588	+6351	+27160	+17956
		-231	-468	-2661	-5792	-77690	-18809
HYPOTHETICAL LOAD		+1867	+493	+102	+8628	+51642	+19166
		-355	-505	-3094	-8069	-102177	-20019

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

Seismic Category	Loading Case	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

CODE



Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT				CISID		PAGE
REV.	0	1	2	3	OF	
MICROFILMED						PAGES
ORIGINATOR						
DATE						8/5/82

Table 6.3 -- Stress Summary of SRV Branch Piping (ME-91,92)

TPIPE TMI PWR S/RV DISCHARGE PIPING (ME- 91,92) (W.O.=045064000) LLCHOU FROM SRV(ME-148) TO PRESSURIZER RELIEF TANK

LLC TMI/EPRI PWR/PORV PIPING EVALUATION (ME91 ,ME92)

A S M E C O D E C L A S S 2 S T R E S S S U M M A R Y

MEMBER NAME	NODAL NAME	EQN NO.	CODE STRESS	ALLOWABLE STRESS	STRESS RATIO	DESCRIPTION
3150 *	314 *	8	5625.	15500.	.36	MAX STRESS
3150 *	314 *	8	5625.	15500.	.36	MAX STRESS RATIO
3290 *	328 *	10	26258.	27000.	.97	MAX STRESS
3290 *	328 *	10	26258.	27000.	.97	MAX STRESS RATIO
3290 *	328 *	11	30145.	42500.	.71	MAX STRESS
3290 *	328 *	11	30145.	42500.	.71	MAX STRESS RATIO
3190 *	318 *	9U	8718.	18600.	.47	MAX STRESS
3190 *	318 *	9U	8718.	18600.	.47	MAX STRESS RATIO
3070 *	306 *	9E	19900.	27900.	.71	MAX STRESS
3070 *	306 *	9E	19900.	27900.	.71	MAX STRESS RATIO
3070 *	306 *	9F	35129.	37200.	.94	MAX STRESS
3070 *	306 *	9F	35129.	37200.	.94	MAX STRESS RATIO
3290 *	328 *	PR	32868.	36480.	.90	MAX STRESS
3290 *	328 *	PR	32868.	36480.	.90	MAX STRESS RATIO
3310 *	329 *	AV	24597.	600000.	.04	MAX STRESS
3310 *	329 *	AV	24597.	600000.	.04	MAX STRESS RATIO

TOTAL NUMBER OF PIPE MEMBERS WITH NODAL POINTS GREATER THAN A THRESHOLD STRESS RATIO

EQUATION 8.....	0
EQUATION 10.....	0
EQUATION 11.....	0
EQUATION 9U.....	0
EQUATION 9E.....	0
EQUATION 9F.....	0
PIPE RUPTURE....	0
ACTIVE VALVE....	0





Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT				CISID			PAGE
REV.	0	1	2	3	OF		
MICROFILMED					PAGES		
ORIGINATOR	L. J. H. C. U.						
DATE	7/30/82						

## 7.2.1 MATERIAL PROPERTY AND PIPE CROSS SECTION

### MATERIAL PROPERTIES

MATERIAL NUMBER	COLD ELASTIC MODULUS (PSI)	POISSONS RATIO	THERMAL EXPANSION COEFFICIENT (IN/IN/FA)	MEMBER TEMPERATURE (FA)	HOT ELASTIC MODULUS (PSI)	COMMENT
1	28300000.0	.300	.000009760	550.00	28300000.0	SA312
2	28300000.0	.300	.000009650	450.00	28300000.0	SA312
3	28300000.0	.300	.000009520	340.00	28300000.0	SA312

### PIPE MEMBER CROSS SECTION TYPES

SECTION NUMBER	OUTSIDE DIAMETER (IN)	WALL THICKNESS (IN)	AXIAL AREA (IN**2)	SHEAR AREA (IN**2)	FLEXURAL INERTIA (IN**4)	WEIGHT/LENGTH (LB/FT)	SECTION DESCRIPTION
1	6.625	.2800	5.58	2.79	28.1	26.57	6"PIP
2	4.500	.2370	3.17	1.59	7.2	15.45	4"PIP
3	10.750	.3650	11.91	5.96	160.7	49.43	10"PIP
4	6.625	.5600	10.67	5.37	49.5	.02	SRV
5	4.500	.4740	6.00	3.03	12.3	.02	PORV
6	18.000	8.5000	253.68	180.28	5152.9	38.00	6"EXT
7	12.000	6.5000	112.31	91.83	1017.8	28.00	4"EXT

### CLASS 2 POSTPROCESSOR MATERIALS

MATL ID NUM	MATL CLASS	DESIGN PRESSURE (PSIG)	PEAK PRESSURE (PSIG)	ALLOWABLE COLD (PSI)	STRESSES HOT (PSI)	YIELD STRESS (PSI)
1	2	700.00	700.00	18500.00	15500.00	30000.00
2	2	700.00	700.00	18500.00	15500.00	30000.00
3	2	2500.00	2500.00	18500.00	15500.00	30000.00

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	DEPARTMENT NAME	PIPING	DEPT. NO.	0432	FILING CODE	ME-
	PROJECT NAME	TMI-1	* D. NUMBER	04-4546-000	PAGE	
SUBJECT			ORIGINATOR	VERIFIER		
2.8 VALVE ACCELERATIONS			<i>L. H. Hou</i>			
			DATE	07/16/82	DATE	

TAG NO.	RC-RV2		RC-V2			
JOINT NO.	V144		V146			
ISO NO.	B-312-565 Rev.4		B-312-565 Rev.4			
SRSS LOAD TOTALS	A <sub>1T</sub>	1.098	0.400			
	A <sub>2T</sub>	0.353	0.906			
	A <sub>3T</sub>	0.922	1.065			
	ACCELERATION	ALLOWABLE	ACCELERATION	ALLOWABLE	ACCELERATION	ALLOWABLE
VERTICAL (A <sub>2T</sub> )	0.353 g	2 g	0.906 g	2 g		
HORIZONTAL *	1.434 g	3 g	1.137 g	3 g		


TAG NO.	RC-RV1A		RC-RV1B			
JOINT NO.	354		250			
ISO NO.	55-312-580 Rev.3		B-312-579-Rev.3			
SRSS LOAD TOTALS	A <sub>1T</sub>	0.024	0.			
	A <sub>2T</sub>	0.001	0.			
	A <sub>3T</sub>	0.201	0.035			
	ACCELERATION	ALLOWABLE	ACCELERATION	ALLOWABLE	ACCELERATION	ALLOWABLE
VERTICAL (A <sub>2T</sub> )	0.001 g	2 g	0. g	2 g		
HORIZONTAL *	0.201 g	3 g	0.035 g	3 g		

\* HORIZONTAL ACCELERATION =  $\sqrt{(A_{1T})^2 + (A_{3T})^2}$

6.2 As a result of the analysis, some tentative conclusions and recommendations are as follows:

- a. After adding one 3 kip snubber at joint no. 346 (ME-91,92), the maximum stress of the S/RV discharging piping will be within the allowable limits.
- b. Valve nozzle loads shall be re-evaluated by the vendors.
- c. Tank nozzle loads are lower than the allowable limits used for previous design. (see next page)
- d. Spring and rigid supports need to be re-evaluated due to load changed by the piping filled with subcooled water. (see Section 6.1 comparison results)

CONSOLIDATED<sup>®</sup>  
AND  
HANCOCK  
VALVES FOR  
NUCLEAR SERVICE



The most respected names in industrial control and measurement    ASHCROFT, HANCOCK and CONSOLIDATED<sup>®</sup>

**DRESSER**


DRESSER INDUSTRIAL VALVE & INSTRUMENT DIVISION

DRESSER INDUSTRIES, INC.

ALEXANDRIA, LOUISIANA 71301

## safety valve — series 31700

Pressurized water reactor service  
Primary vessel service; closed loop  
systems



\*U.S. patent #2,643,671; other patents pending.

High capacity, flat seated, reaction type safety valve with enclosed bonnet, balanced bellows, and auxiliary balanced piston, this CONSOLIDATED Maxiflow safety valve is designed to assure a maximum degree of tightness and operate under variable back pressure conditions on a pressurized water reactor.

packing around stainless steel shaft prevents leakage to atmosphere.

unique in closed bonnet valves, this feature prevents damage to spindle bearing points.

specially designed to eliminate eccentric loading and to provide full relieving capacity at minimum accumulation.

assures pressure balance in the event of damage to bellows. Also acts as a lift stop.

Inconel 600 suitable for back pressures up to 750 psi.

the machined spherical tip, and a small flat at the extreme end provides a better bearing point than a ball which might break, as a result of stress concentration. Bearing surfaces are stellite to eliminate galling.

eliminates distortion due to thermal stresses. Temperature differentials quickly equalized and permanent tightness assured.

prevents misalignment due to unusual tightening of flange studs.

permits higher external loading than conventional valves; see Force Diagram on page 15.

alloy steel forgings. Precision machined inlet surfaces provide optimum entrance conditions for steam flow, greater resistance to steam erosion and corrosion.

### Thermodisc® Seat

The disc seat in the CONSOLIDATED pressurizer safety valve is the Thermodisc design. The experimental work conducted by a research institute some years ago for CONSOLIDATED valves, demonstrated conclusively that extreme tightness on steam service required some means of compensating for temperature variations around the periphery of the seat bushing. This was accomplished by the Thermodisc® seat construction, a patented feature of CONSOLIDATED valves.

The guiding of the stainless steel through bushing in the flanged inlet valve is located in the upper part of the base as close to the seating area as possible. Locating the guiding area at this point permits better alignment of the seat and disc, assuring a greater degree of tightness. This eliminates the possibility of misalignment of the nozzle caused by uneven torque on the bolting when the flange of a safety valve with a through bushing is installed on a unit.

Safety valve is popped on steam. A standard test is conducted on steam, with condensate leakage maximum of 2 cc/hr. per hour after valve has "popped" and the pressure reduced to 95% of set pressure.


Experience has proven that the spring load must be transmitted to the valve disc with the load imposed as close to the seating surface as possible. The CONSOLIDATED valve design has this feature, assuring proper alignment and load distribution at the seating surface. This prevents the disc from sliding across the seat on opening and closing. In addition, the accurately centered position of the disc relative to the seat is maintained by a close tolerance guide between the disc and the disc holder.

The CONSOLIDATED pressurizer safety valve has a machine spherical tip on the spindle and a very small machined flat at the extreme end. It has been proven that this provides a better bearing than a perfect ball since stress concentration at one point on the ball will normally cause breakage of the ball.

Standard body material is ASTM A-351, Grade CF8M stainless steel to eliminate corrosion due to borated coolant water.

Material is Inconel 600, with suitable back pressure to 750 psi. Seal plate beneath spindle is welded to the disc nut which is in turn welded to the bellows. This design feature prevents any gas or steam from escaping past the disc and spindle.

The auxiliary piston in the CONSOLIDATED pressurizer safety valve compensates for bellows failure, allowing the valve to function properly and protecting equipment until the bellows can be replaced.



RECOMMENDED MAXIMUM EXTERNAL LOADS


VALVE TYPE	F <sub>x</sub> Lbs.	F <sub>y</sub> Lbs.	F <sub>z</sub> Lbs.	MAXIMUM LOADS	
				M <sub>x</sub> (In.-Lbs.)	M <sub>y</sub> & M <sub>z</sub> (In.-Lbs.)
31719-A	250	125	125	1750	875
31729-A	270	135	135	2294	1147
31739-A	670	335	335	6700	3320
31759-A	700	350	350	7000	3500
31749-A	700	350	350	7000	3500
31709K-A	600	300	300	6000	2900

DISTRIBUTION OF SIMULTANEOUS EXTERNAL LOADS\*

If F <sub>x</sub> is:	one horizontal load may be:	and the other may be:
100	0	0
90	50	50
75	75	75
50	90	50
0	100	0

\*Values shown are % of maxima






**DIMENSIONS**

SIZE AND TYPE	ALL TEMPERATURE CLASSES								Dismantling Height	Approx. Weight Lbs.
	A	B (300#)	B (600#)	C	D	E	F	G		
1½" 31719	7¼	7¼	8¾	29¾	1¼	2¾	9	13	39	200
2" 31729	7¾	8½	9¼	36½	1¾	2½	10¼	18¾	49	240
2½" 31709K	9	9¾	10¼	41¾	1¾	3¾	10¾	20¾	66¼	500
2½" 31739	9	9¾	10¼	41¾	1¾	3¾	10¾	20¾	66¼	500
3" 31759	8¾	10	11½	45½	1¾	3¾	14	18¾	70	800
3" 31749	8¾	10	11½	45½	1¾	3¾	14	18¾	70	800

**MATERIALS**

1	Base	ASTM A351 Grade CF8M Stainless Steel
2	Nozzle	ASTM A182 Grade F347 Stainless Steel
3	Nozzle Gasket	AISI 304 and Asbestos
4	Lower Adj. Ring	19% Chrome Stainless Steel to Eng. Inst. MA-12
5	Lower Adj. Ring Pin	13% Chrome Stainless Steel to Eng. Inst. MA-7
6	Disc	ASTM A461 Grade 688 Nickel Base Alloy
7	Guide	Monel Alloy 505
8	Bellows Assembly	
8A	Bellows	ASME SB168 Inconel 600
8B	Bellows Flange	ASME SA240 Type 316L Stainless Steel
8C	Disc Nut	ASME SA182 Grade F316L Stainless Steel
8D	Flange Adaptor	ASME SA182 Grade F316L Stainless Steel
9	Guide Gaskets	AISI 304 and Asbestos
10	Disc Holder	Monel Alloy 505
11	Upper Adj. Ring	19% Chrome Stainless Steel to Eng. Inst. MA-12
12	Upper Adj. Ring Pin	13% Chrome Stainless Steel to Eng. Inst. MA-7
13	Top Adj. Ring	19% Chrome Stainless Steel to Eng. Inst. MA-12
14	Top Adj. Ring Pin	13% Chrome Stainless Steel to Eng. Inst. MA-7
15	Spindle	ASTM A182 Grade F316 Stainless Steel
16	Lift Stop	Monel Alloy 505
17	Support Plate	AISI 410 Stainless Steel
18	Support Plate Gaskets	AISI 304 and Asbestos
19	Floating Washer	Monel Alloy 400
20	Washer Retainer	AISI 410 Stainless Steel
21	Retainer Cap Screw	AISI 316 Stainless Steel
22	Top Spring Washer Assembly	
22A	Spring Washer	ASTM A105 Grade II Carbon Steel
22B	Pin	Chrome Vanadium Steel
23	Bottom Spring Washer	ASTM A105 Grade II Carbon Steel
24	Spring	EHW Tungsten Steel to Eng. Inst. MA-16
25	Bonnet Assembly	
25A	Bonnet	ASTM A216 Grade WCB Carbon Steel
25B	Bonnet Plug	ASTM A105 Grade II Carbon Steel
26	Bonnet Stud	ASTM A193 Grade B7 Alloy Steel
27	Stud Nut	ASTM A194 Grade 2H Alloy Steel
28	Compression Screw	ASTM B98 Alloy 661
29	Compression Screw Nut	ASTM B199 Alloy 118 Leaded Nickel Silver
30	Release Nut	AISI C1018 Carbon Steel
31	Cap	ASTM A216 Grade WCB Carbon Steel
32	Cap Gasket	AISI 316 with Asbestos Filler
33	Cap Stud	ASTM A193 Grade B7 Alloy Steel
34	Cap Stud Nut	ASTM A194 Grade 2H Alloy Steel
35	Lever Shaft	13% Chrome Stainless Steel to Eng. Inst. MA-7
36	Lifting Fork	ASTM A47 Grade 35018 Malleable Iron
37	Lever	ASTM A47 Grade 35018 Malleable Iron
38	Shaft Collar (Not Shown)	13% Chrome Stainless Steel to Eng. Inst. MA-7
39	Retaining Ring (Not Shown)	17-7 PH Stainless Steel
40	Packing (Not Shown)	Asbestos
41	Packing Nut (Not Shown)	13% Chrome Stainless Steel to Eng. Inst. MA-7
42	Lever Nut (Not Shown)	ASTM A194 Grade 1 Steel
43	Ring Pin Gaskets	AISI 316 with Asbestos Filler



**CONNECTION**

Orifice Size	Orifice Dis. Area Sq. Inches	Orifice Designation	Inlet*	Outlet**
			ANSI Flange	ANSI Flange
1½	.994	1	1½" 2500#	4" 300# R. F.
2	1.431	2	2" 2500#	4" 300# R. F.
2½	1.840	K	2½" 2500#	6" 300# R. F.
2½	2.545	3	2½" 2500#	6" 300# R. F.
3	3.341	5	3" 2500#	6" 300# R. F.
3	3.976	4	3" 2500#	6" 300# R. F.

\*Flange Thickness may exceed ANSI — See Dimension Table  
\*\*Also Available with 600# Outlet.

**VALVE SIZES**

Pres.	Temp. Degrees F.	Valve Size	Valve Size					Pres.	Connection** ANSI Flange	
			1½"	2"	2½"	2½"	3"			
		Orifice Size	.994	1.431	1.840	2.545	3.341			
		Temp. Desig.	1	2	K	3	5			
2500	650°	A	31719A	31729A	31709KA	31739A	31759A	31749A	2500	Inlet 2500# R. F. Outlet 300# R. F.

\*\*Flange thickness may exceed ANSI (see dimension table); also available with 600# outlet.

Capacities shown on pages 18 and 19 — Outlet reaction shown on Pages 8 and 9.




<b>GILBERT ASSOCIATES, INC.</b> ENGINEERS AND CONSULTANTS READING, PA.	DEPARTMENT NAME	DEPT. NO.	FILING CODE
	PROJECT NAME	W.O. NUMBER	PAGE
	PIPING ENGINEERING	0020	PA-17719
	TRE UNIT-1	12-245-1-7	

SUBJECT: REPAIR WELDED MAN. TANK (20" DIA) ALLOWABLE LOADS

ORIGINATOR
DATE 1/16/80
VERIFIER
DATE 6/2/80

10" B CONNECTING  
PIPE



$A_p = \text{METAL AREA (10" } \phi)$   
 $A_p = 11.91 \text{ IN}^2$   
 $Z_p = \text{SECTION MODULUS}$   
 $= 27.91 \text{ IN}^3$   
  
 $Temp = 500^\circ F$   
 MATERIAL:  
 STAINLESS STEEL  
 AUSTENITIC TYPE 304  
 $S_h = 15,900 \text{ psi}$

VESSELS: (NON-ROTATING EQUIPMENT)

$$F_{y \text{ AXIAL}} = 0.035 A_p \cdot S_h$$

$$= 0.035 (11.91) (15,900)$$

$$F_{y \text{ AXIAL}} = 6628 \text{ lbs.} \times 1.2 (OCE) = \underline{7954 \text{ lbs.}}$$

$$\sqrt{F_{x \text{ SHEAR}}^2 + F_{z \text{ SHEAR}}^2} = 0.035 A_p \cdot S_h$$

$$= 6628 \text{ lbs.} \times 1.2 (OCE) = \underline{7954 \text{ lbs.}}$$

$$M_{y \text{ TORSIONAL}} = 0.3 Z_p \cdot S_h$$

$$= 0.3 (27.91) (15,900)$$

$$M_{y \text{ TORSIONAL}} = 142,671 \text{ in-lbs} \times 1.2 (OCE) = \underline{171,205 \text{ in-lbs}}$$

$$\sqrt{M_{x \text{ BENDING}}^2 + M_{z \text{ BENDING}}^2} = 0.3 Z_p \cdot S_h$$

$$= 142,671 \text{ in-lbs} \times 1.2 (OCE) = \underline{171,205 \text{ in-lbs}}$$

FILING CODE

GILBERT ASSOCIATES, INC.  
 ENGINEERS AND CONSULTANTS  
 READING, PA.

DEPARTMENT NAME  
 PROJECT NAME  
 T100-1

DEPT. NO. 0527  
 FILING CODE  
 W.O. NUMBER  
 PAGE

SUBJECT STRESS ANALYSIS OF UNREINFORCED FIBERGLASS TEE


ORIGINATOR  
 J. R. [unclear]

DATE 5/28/50

VERIFIER

DATE

MODEL OF TEE:  
 (unreinforced fiberglass)



$\therefore$  stress is ok.

FILING  
 CODE

memorandum



Gilbert/Commonwealth

Handwritten notes: Bunker 17411, 2/11/82

to: DISTRIBUTION

from: P. L. Bunker

subject: TMI-1 PORV/SRV Meeting with GPU Nuclear May 17, 1982, Reading

May 18, 1982

Minutes of Meeting

Purpose

A meeting was held on Monday, May 17, 1982 at GAI in Reading between GPU and GAI. The purpose was to discuss GAI's ability to provide preliminary results to GPU on an accelerated basis. PORV and SRV valve characteristics were also discussed.

Present

<u>GAI</u>	<u>GPU</u>
D. E. Aunkst	J. D. Abramovici
R. R. Brems	U. S. Bhachu
P. L. Bunker	
J. M. Cajigas	
M. Z. Lee	

Documents Exchanged

GAI memo Bunker to Brems, "TMI-1 Recommended Valve Inlet Conditions for S/RV Discharge Piping Analysis" May 17, 1982.

Discussion

1. Schedule Acceleration

GAI indicated that a preliminary evaluation of the support loads could be available to GPU 4 working days after the preliminary RELAPS Force data is available. This will enable GPU to begin procurement of any required snubbers.

2. Progress Reporting

GAI will call J. Abramovici or U. S. Bhachu each Thursday to report progress. Followup will be by telephone conversation memorandum.

3. PORV/SRV Inlet Conditions

The GAI interpretation of the B&W "Plant Conditions Justification Report

DISTRIBUTION  
P. L. Bunker  
May 18, 1982  
Page 2

was given to GPU. GPU will review and call J. Cajigas by May 19, 1982. At that time agreement should be reached between GPU and GAI as to the valve inlet conditions.

4. PORV/SRV Valve Characteristics

The following items were discussed and tentatively agreed upon unless better information is obtained from Dresser.

- (A) Valve Flow Rates to be used in RELAP5 analysis:  
Use the rated steam flow and apply a 90% factor for derating and a 5% error factor.

PORV

$$m = \frac{100,000}{.90} \text{ lbm/hr} \times 1.05 = 116667 \frac{\text{lbm.}}{\text{hr.}} @ 2300 \text{ psig}$$

Safety Valves

$$m = \frac{317973}{.90} \text{ lbm/hr} \times 1.05 = 370968 \frac{\text{lbm}}{\text{hr}} @ 2500 \text{ psig}$$

- (B) Valve opening times:

Safety valves;

- (a) Use .040 seconds for subcooled water discharge  
(b) Use .012 seconds for steam discharge

PORV;


- (a) Use .060 seconds for subcooled water discharge

- (C) PORV Cv vs. Stroke

- (a) GPU does not have a Cv vs. stroke curve.  
(b) GAI will contact Jim Correa (GPU) and discuss the problems. Jim or GAI will contact Dresser.

- (D) Safety Valve Ring Settings

GPU does not have this information. They expect ring settings to be changed after valves are relocated.



P. L. BUNKER  
NUCLEAR ANALYSIS

PLB:jah

cc: Attendees  
R. E. Anderson  
G. M. Kowal  
R. Murthy  
M. M. Waselus

ATTACHMENT A

SEISMIC CRITERIA DOCUMENTS

October 9, 1969

October 9, 1969

TO: Mr. B. R. Wheelock, Jr.

FROM: K. E. Hodland

SUBJECT: Three Mile Island Nuclear Station  
Piping - Seismic Analysis  
GAR-1192

In accordance with our previous discussion and in reply to your memo dated September 30, 1969; the following information should answer your request.

The seismic pipe analysis for Class I piping is performed with "QUAKE-PIPE STRESS", which is based on maximum response due to 0.06g horizontal ground motion, using 0.5% damping, for a system's undamped natural frequency. In addition the effect of vertical ground motion is specified by the PSAR to be 2/3 of the horizontal ground motion. Refer to Fig. 3.1.1, Amendment #6 of the PSAR. The factor of 2/3 for the vertical seismic stresses must be applied to the results from "QUAKE-PIPE STRESS" before combining these results with the horizontal seismic stresses and other load combinations.

For maximum hypothetical earthquake equal to 0.12g horizontal ground motion, the previous results due to 0.06g horizontal ground motion shall be doubled; and similar for vertical ground motion.

Amplification factors for equipments at different elevation located in various buildings have been furnished by D. A. Godfrey in his memo to C. H. Ritting dated January 13, 1969. These amplification factors shall be applied to the final results as obtained from "QUAKE-PIPE STRESS".

REACTOR BUILDING

Elevation:

231'-0"  
 303'-0"  
 326'-0"  
 346'-0"  
 365'-0"  
 436'-0"

Reactor Building, Interior  
 Structures, Amplification Factors

1.00  
 2.00  
 2.85  
 3.72  
 4.45  
 —

Reactor Building Shell  
 Amplification Factors

1.00  
 1.00  
 1.60  
 2.04  
 2.65  
 4.12

For piping located at different elevations, use the most conservative amplification factor.

... the above elevations.  
The first mode horizontal frequency is 3.82 cps for the reactor building.

*H. E. Madland*

H. E. Madland

LEN:flg

- cc: C. H. Eitting
- W. R. Shade
- W. E. Mack
- J. E. Eichen, Jr.
- J. Grselkowitz
- D. K. Cronberger
- W. J. Leininger
- R. Altschuler




FACTOR  
 Spectrum  
 X2  
 X2.85  
 X3.72  
 X4.45

for basic  
 spectrum  
 1. - basic  
 spectrum  
 2. - basic  
 spectrum  
 3. - basic  
 spectrum  
 4. - basic  
 spectrum  
 5. - basic  
 spectrum  
 6. - basic  
 spectrum  
 7. - basic  
 spectrum  
 8. - basic  
 spectrum  
 9. - basic  
 spectrum  
 10. - basic  
 spectrum  
 11. - basic  
 spectrum  
 12. - basic  
 spectrum  
 13. - basic  
 spectrum  
 14. - basic  
 spectrum  
 15. - basic  
 spectrum  
 16. - basic  
 spectrum  
 17. - basic  
 spectrum  
 18. - basic  
 spectrum  
 19. - basic  
 spectrum  
 20. - basic  
 spectrum

RESPONSE SPECTRUM  
 FIGURE 3.1-1  
 AMEND. 6 (1-8-68)

FOR .06 g. Eur



2029

of the response (i.e., stress, shear, moment, or deflection) of each contributing mode due to vertical motion to the corresponding absolute values of the response of each contributing mode due to horizontal motion.

### Damping Factors

The following damping factors have been applied to the maximum earthquake in the seismic design of components and structures:

<u>Component or Structure</u>	<u>Percent of Critical Damping</u>
1. Reactor Building	2.0
2. Concrete Support Structures Inside the Reactor Building	2.0
3. Assemblies and Structures	
(a) Bolted or Riveted	2.5
(b) Welded	1.0
4. Vital Piping Systems	0.5
5. Other Concrete Structures above ground	5.0

Scaled plots of stress resultants, stress couples, shear, and deflections for seismic load are shown in Figures 5-20, 5-21, 5-22, 5-23, and 5-24.

### ALLOWABLE STRESS

OBE - increase by 33%

OBE - up to yield

# MEMORANDUM

GILBERT ASSOCIATES, INC.

June 17, 1970

TO: Mr. C. H. Ritting  
FROM: D. D. Krause  
SUBJECT: Three Mile Island Nuclear Station  
Unit No. 1  
Seismic Design

Refer to K. E. Hodland's memo of January 9, 1970. As mentioned there, normal engineering practice often requires the development and utilization of new information as it becomes available.

Accompanying this memo is a guide entitled "Seismic Design for Equipment Specifications". The typical seismic design requirements described therein remain the same for any equipment mounted on the included structures.

These floor response spectrum curves have been generated from output of a program based on the report Seismic Analysis of Equipment Mounted on a Building Structure by J. H. Ely and J. H. Rossett of MIT. Input to the new program is from the SHAKE program. The curves are based on the .06g design earthquake with 5% structural damping and 0.5% equipment damping. Curves for other buildings will be available in the near future.

D.D.K.

D. D. Krause

DDK:flg  
Attachment

cc: W. R. Shado  
K. T. Marose  
H. F. Lerona  
C. Chen  
W. Meck  
J. Behen, Jr.  
E. R. Wadlock, Jr.  
A. H. Larson  
W. Shields  
W. Spiler  
D. K. Cronberger  
W. J. Leininger  
K. Akselsen  
L. Foster

Note: FRANK BELL HAS  
FOLDER WITH COMPUTER  
OUTPUT AND CURVES FOR  
{ REAC  
AUX, FUEL, CONT.  
INTERM,  
INTAKE

1-17-71

TABLE OF CONTENTS

	<u>Page No.</u>
Typical Seismic Requirements for Equipment Specifications	1
Choosing the Appropriate Floor Response Spectrum	2
Fig. 1 Model for Auxiliary, Fuel Handling, and Control Buildings	3
Fig. 2 Floor Response Spectrum for Mass Point 1	4
Fig. 3 Floor Response Spectrum for Mass Point 2	5
Fig. 4 Floor Response Spectrum for Mass Point 3	6
Fig. 5 Floor Response Spectrum for Mass Point 4	7
Fig. 6 Floor Response Spectrum for Mass Point 5	8
Fig. 7 Model for Reactor Building Interior Concrete	9
Fig. 8 Floor Response Spectrum for Mass Point 1	10
Fig. 9 Floor Response Spectrum for Mass Point 2	11
Fig. 10 Floor Response Spectrum for Mass Point 3	12
Fig. 11 Floor Response Spectrum for Mass Point 4	13
Fig. 12 Floor Response Spectrum for Mass Point 5	14

## TYPICAL SEISMIC REQUIREMENTS FOR EQUIPMENT SPECIFICATIONS

The assembled switch, components and wiring shall be designed so that the function of the circuits or components will be performed in accordance with the specification when subjected to the horizontal acceleration plus two-thirds ( $2/3$ ) of the vertical acceleration acting simultaneously.

In addition, equipment, accessories, controls, components, and wiring shall not dislodge nor suffer relative movement resulting in any loss of function for the seismic condition:

2X (horizontal accel.) plus 2X ( $2/3$  vertical accel.) acting simultaneously.

### Horizontal Acceleration:

Calculate the natural period of the equipment for the horizontal direction chosen such that the corresponding acceleration from the response spectrum is maximum.

If the natural period is unknown, use the maximum possible acceleration of the spectrum.

### Vertical Acceleration:

Calculate the natural period of the equipment in the vertical direction. From the appropriate response spectrum, find the corresponding acceleration. Similarly, if the natural period is unknown, use the maximum possible acceleration for the particular response spectrum.

### Choosing the Appropriate Floor Response Spectrum:


Use the floor response spectrum for the floor closest to the location of the equipment.

For example, given a piece of equipment that must be specified for seismic requirements and is located in the Auxiliary Building at El. 310'.

Refer to Fig. 1 showing the mass model for the Auxiliary, Fuel Handling and Control Buildings. The closest mass point to El. 310' is mass point 5 at El. 302'-6". Therefore, Fig. 6 showing the floor response of mass point 5 would be included in the specifications along with the typical seismic requirements.

METROPOLITAN EDISON COMPANY	MADE	GILBERT ASSOCIATES, INC.		
	CHK'D.	ENGINEERS AND CONSULTANTS		
	SG. CP.	READING, PENNA.		
	CP. DPH.		9	
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV.

REACTOR BUILDING  
INTERIOR CONCRETE




LUMPED MASS MODEL  
FOR DYNAMIC ANALYSIS

FIG. 7



EUGENE DIETZGEN CO.  
MADE IN U. S. A.

NO. 340R-1310 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
3 CYCLES X 10 DIVISIONS PER INCH



Acm (g)

8.0 - 31 - 6.0

4.0

2.0

0.00 1 1 1 0.10 0.08 0.10 0.20 0.40 0.60 0.80 1.00 T<sub>em</sub> (sec)



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT

CISID

PAGE

REV.

0

1

2

3

MICROFILMED

ORIGINATOR

L. L. L. L.

DATE

7/20/82

OF

PAGES

## 7. DESIGN INPUT

### 7.1 Assumptions

- a. Piping filled with water was used in the completed analysis (DW+THERMAL+OBE+BLOWDOWN). Additionally, piping filled with steam was analyzed in deadweight case only.
- b. Three piping branches are structurally independent each other.
- c. Valves were simulated as the same size pipe but doubled pipe thickness.
- d. 450°F was used to piping thermal expansion analysis. (ref. to AEA's RELAP5 analysis)

### 7.2 Input Data for Time History, OBE, THERMAL



Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT				CISID	PAGE
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR	E.K.H.				
DATE	7/26/72				

TIPIE VERSION G/C4.2  
RUN DATE- 82/06/17.

TRIPLE TRI PUR S/RU DISCHARGE PIPING (ME-162.93) (U.O.-045864000) LLCHOU  
FROM PORV(ARC-RV2) TO PRESSURIZER RELIEF TANK  
SUPPORT AND LUG DESIGN INFORMATION

MODE	SUPPORT	DESIGN	TRAILR	MAX PIPE	MOVEMENTS	NORMAL	EXPAN	OCCAS	EMERGENCY	REFAULTED
NAME	DIR	TYP	CLS	X	Y	Z			(LUG DSGM	LOAD)
M100	X	AM	2	0.000	0.000	0.000	91.	31.	-37.	51.
	Y	AM	2	0.000	0.000	0.000	0.	262.	-267.	282.
	Z	AM	2	0.000	0.000	0.000	84.	68.	-81.	119.
	XM	AN	2	0.000	0.000	0.000	57.	302.	-359.	492.
	YM	AN	2	0.000	0.000	0.000	0.	64.	-83.	122.
	ZM	AN	2	0.000	0.000	0.000	0.	185.	-126.	175.
102	X	RR	2	0.000	-0.538	0.000	0.	125.	-150.	208.
	Y	RR	2	0.000	0.000	0.000	0.	91.	-188.	30000.
	Z	RR	2	0.000	0.000	0.000	0.	213.	-341.	30000.
103	X	DS	2	0.000	-0.656	0.000	0.	244.	-440.	30000.
	Y	DS	2	0.000	0.000	0.000	0.	213.	-440.	30000.
	Z	DS	2	0.000	1.492	0.000	1331.	168.	-244.	15234.
104	X	RR	2	0.000	1.492	0.000	0.	172.	-449.	849.
	Y	RR	2	0.000	1.492	0.000	0.	172.	-449.	849.
	Z	RR	2	0.000	1.669	0.000	0.	209.	-204.	30000.
107	X	RR	2	0.000	1.669	0.000	0.	571.	-572.	30000.
	Y	RR	2	0.000	1.669	0.000	0.	571.	-572.	30000.
	Z	RR	2	0.000	1.669	0.000	0.	571.	-572.	30000.
112	X	CS	2	0.000	0.000	0.000	0.	316.	-316.	12334.
	Y	CS	2	0.000	0.000	0.000	0.	316.	-316.	12334.
	Z	CS	2	0.000	0.000	0.000	0.	316.	-316.	12334.
5113	X	DS	2	0.000	-0.35	0.000	0.	409.	-506.	12241.
	Y	DS	2	0.000	-0.35	0.000	0.	409.	-506.	12241.
	Z	DS	2	0.000	-0.35	0.000	0.	409.	-506.	12241.
116	X	US	2	0.000	0.000	0.000	0.	77.	-87.	14487.
	Y	US	2	0.000	0.000	0.000	0.	77.	-87.	14487.
	Z	US	2	0.000	0.000	0.000	0.	77.	-87.	14487.
117	X	DS	2	0.000	-0.550	0.000	0.	539.	-548.	30000.
	Y	DS	2	0.000	-0.550	0.000	0.	539.	-548.	30000.
	Z	DS	2	0.000	-0.550	0.000	0.	539.	-548.	30000.
120	X	RR	2	0.000	0.000	0.000	0.	115.	-139.	30000.
	Y	RR	2	0.000	0.000	0.000	0.	115.	-139.	30000.
	Z	RR	2	0.000	0.000	0.000	0.	115.	-139.	30000.
121	X	RR	2	0.000	0.000	0.000	0.	275.	-288.	18799.
	Y	RR	2	0.000	0.000	0.000	0.	275.	-288.	18799.
	Z	RR	2	0.000	0.000	0.000	0.	275.	-288.	18799.
121	X	RR	2	0.000	0.000	0.000	0.	591.	-592.	12223.
	Y	RR	2	0.000	0.000	0.000	0.	591.	-592.	12223.
	Z	RR	2	0.000	0.000	0.000	0.	591.	-592.	12223.
124	X	US	2	0.000	0.000	0.000	0.	109.	-109.	30000.
	Y	US	2	0.000	0.000	0.000	0.	109.	-109.	30000.
	Z	US	2	0.000	0.000	0.000	0.	109.	-109.	30000.
129	X	AM	2	0.000	0.000	0.000	0.	1118.	-1136.	1191.
	Y	AM	2	0.000	0.000	0.000	0.	1118.	-1136.	1191.
	Z	AM	2	0.000	0.000	0.000	0.	1118.	-1136.	1191.
132	X	RR	2	0.000	0.000	0.000	0.	296.	-296.	18595.
	Y	RR	2	0.000	0.000	0.000	0.	296.	-296.	18595.
	Z	RR	2	0.000	0.000	0.000	0.	296.	-296.	18595.
133	X	DS	2	0.000	0.000	0.000	0.	445.	-445.	30000.
	Y	DS	2	0.000	0.000	0.000	0.	445.	-445.	30000.
	Z	DS	2	0.000	0.000	0.000	0.	445.	-445.	30000.
134	X	RR	2	0.000	0.000	0.000	0.	537.	-537.	11642.
	Y	RR	2	0.000	0.000	0.000	0.	537.	-537.	11642.
	Z	RR	2	0.000	0.000	0.000	0.	537.	-537.	11642.
137	X	CS	2	0.000	0.000	0.000	0.	849.	-849.	30000.
	Y	CS	2	0.000	0.000	0.000	0.	849.	-849.	30000.
	Z	CS	2	0.000	0.000	0.000	0.	849.	-849.	30000.
5138	X	DS	2	0.000	0.000	0.000	0.	1369.	-1369.	1369.
	Y	DS	2	0.000	0.000	0.000	0.	1369.	-1369.	1369.
	Z	DS	2	0.000	0.000	0.000	0.	1369.	-1369.	1369.
148	X	AM	2	0.000	0.000	0.000	0.	2176.	-2176.	2176.
	Y	AM	2	0.000	0.000	0.000	0.	2176.	-2176.	2176.
	Z	AM	2	0.000	0.000	0.000	0.	2176.	-2176.	2176.
149	X	RR	2	0.000	0.000	0.000	0.	3861.	-3861.	3861.
	Y	RR	2	0.000	0.000	0.000	0.	3861.	-3861.	3861.
	Z	RR	2	0.000	0.000	0.000	0.	3861.	-3861.	3861.



Gilbert Associates, Inc.  
Reading, Pennsylvania  
CALCULATION

TPIPE TRI PUR S/RU DISCHARGE PIPING (ME-88.89) (U.O.-045064000) LLCHOU  
FROM SRU(ME-147) TO PRESSURIZER RELIEF TANK

TPIPE VERSION G/C4.2  
RUN DATE- 82/06/18.

SUPPORT AND LUG DESIGN INFORMATION

NODE NAME	SUPPORT DIR	TYP	CLS	DESIGN TRAVEL			MAX PIPE MOVEMENT			NORMAL SUST.	REUPSET		EMERGENCY		FAULTED		LBS		
				+	-		X	Y	Z		+ EXPAN	- OCCAS	+ OCCAS	-	+ OCCAS	-			
H200	X	AN	2				0.000	0.000	0.000	-2.	208.	0.	5.	-5.	7.	-7.	15.	-15.	LBS
	Y	AN	2				0.000	0.000	0.000	-1730.	0.	-534.	2937.	-2937.	2937.	-2937.	2987.	-2987.	LBS
	Z	AN	2				0.000	0.000	0.000	-1.	0.	-56.	35.	-35.	44.	-44.	96.	-96.	LBS
	XN	AN	2				0.000	0.000	0.000	-4.	0.	-236.	109.	-109.	186.	-186.	388.	-388.	FTLB
	YN	AN	2				0.000	0.300	0.000	-3.	511.	0.	29.	-29.	76.	-76.	155.	-155.	FTLB
	ZN	AN	2				0.000	0.000	0.000	9.	0.	-872.	16.	-16.	30.	-30.	61.	-61.	FTLB
200	X	RR	2				0.000	.457	0.000	5.	0.	-489.	8.	-8.	16.	-16.	34.	-34.	LBS
																			30000.
200	Z	RR	2				0.000	.457	0.000	2.	132.	0.	54.	-54.	104.	-104.	216.	-216.	LBS
																			30000.
201	X	RR	2				0.000	1.228	0.000	-259.	3488.	0.	398.	-398.	782.	-782.	1613.	-1613.	LBS
																			30000.
201	Z	RR	2				0.000	1.228	0.000	-0.	0.	-199.	455.	-455.	455.	-455.	457.	-457.	LBS
																			30000.
204	X	RR	2				0.000	1.360	.053	258.	0.	-3446.	1733.	-1733.	1733.	-1733.	2309.	-2309.	LBS
																			30000.
204	Y	CS	2	1.345	0.000	0.000	1.360	.053	-567.	0.	-0.								LBS
																			30000.
5206	Z	DS	2	.153	0.000	.289	1.723	.153											LBS
																			11595.
207	Y	CS	2	1.496	0.000	.289	1.667	.086	-520.	0.	0.								LBS
																			18598.
210	Y	US	2	.988	0.000	.405	1.476	.331	-523.	0.	0.								LBS
																			11385.
211	X	DS	2	0.000	-.217	.217	1.004	.538											LBS
																			11282.
214	Y	US	2	.230	0.000	.157	.734	.514	-612.	0.	0.								LBS
																			2640.
215	Y	DS	2	0.000	-.515	.069	.515	.083											LBS
																			567.
218	X	RR	2	0.000	.538	0.000	-61.	817.	0.	1480.	-1480.	1480.	-1480.	1490.	-1490.	1490.	-1490.	1490.	LBS
																			3805.
218	Z	RR	2	0.000	.538	0.000	4.	0.	-2021.	6213.	-6213.	6213.	-6213.	6479.	-6479.	6479.	-6479.	6479.	LBS
																			3805.
219	X	RR	2	0.000	.263	0.000	218.	0.	-3699.	1205.	-1205.	1205.	-1205.	1258.	-1258.	1258.	-1258.	1258.	LBS
																			1541.
219	Z	RR	2	0.000	.263	0.000	-382.	7146.	0.	1543.	-1543.	1543.	-1543.	1578.	-1578.	1578.	-1578.	1578.	LBS
																			6217.
222	Y	US	2	0.000	-.047	.201	.083	.080	-1467.	0.	0.								LBS
																			4739.
227	X	AN	2	0.000	0.000	0.000	-157.	2669.	0.	2162.	-2162.	2162.	-2162.	2188.	-2188.	2188.	-2188.	2188.	LBS
	Y	AN	2	0.000	0.000	0.000	-276.	0.	0.	1147.	-1147.	1147.	-1147.	1613.	-1613.	1613.	-1613.	1613.	LBS
	Z	AN	2	0.000	0.000	0.000	377.	0.	-5032.	1068.	-1068.	1068.	-1068.	2825.	-2825.	2825.	-2825.	2825.	LBS
	XN	AN	2	0.000	0.000	0.000	517.	0.	-372.	1412.	-1412.	1412.	-1412.	5155.	-5155.	5155.	-5155.	5155.	FTLB
	YN	AN	2	0.000	0.000	0.000	822.	0.	-7682.	3489.	-3489.	3489.	-3489.	5547.	-5547.	5547.	-5547.	5547.	FTLB
	ZN	AN	2	0.000	0.000	0.000	-614.	0.	-4665.	2585.	-2585.	2585.	-2585.	5264.	-5264.	5264.	-5264.	5264.	FTLB

SUBJECT	REV.	0
	MICROFILMED	
	ORIGINATOR	<i>W. J. ...</i>
CISID	DATE	<i>7/5/82</i>
PAGE		
	PAGES	
	OF	

PROPRIETARY INFORMATION OF GILBERT ASSOCIATES, INC. - FOR INTERNAL USE ONLY



Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				OF
ORIGINATOR <i>K.L. Kelly</i>				PAGES
DATE <i>7/25/82</i>				

TIPIE VERSION C/C4.2  
RUN DATE-- 82/06/18.

TIPIE TRI PUR S/RU DISCHARGE PIPING (NE- 88.89) (U.O.-045864000) LLCHOU  
FROM SAVINE-147) TO PRESSURIZER RELIEF TANK

SUPPORT AND LUG DESIGN INFORMATION

MODE NAME	SUPPORT DIR TYP CLS	DESIGN TRAILR + X	MAX PIPE MOVEMENT Y	NORMAL Z	SEUPSETBER + EXPAN -	OCCAS -	EMERGENCYBER + OCCAS - (LUG DSGN LOAD) (LUG ALLOW STRS)	1801.	1658.	1658.	1658.	1801.	1801.	LBS
5230	X RR	2	.000	.244	.384	56.	1667.	0.	1658.	1658.	3524.	1801.	30000.	LBS
233	Y V5	2	.194	0.000	.142	.272	.783	-1008.	0.	0.	0.	0.	0.	LBS
5234	X D5	2	.298	0.000	.298	.629	.681	4318.	-4318.	4318.	4318.	4350.	11073.	LBS
237	Z D5	2	0.000	-.318	.524	1.024	.318	2039.	-2039.	2039.	2039.	2682.	18590.	LBS
238	Y D5	2	1.050	0.000	.506	1.050	.387	1424.	-1424.	1424.	1424.	1443.	11879.	LBS
241	Y C5	2	1.095	0.000	.387	1.108	.620	-1046.	0.	0.	0.	0.	12326.	LBS
242	X D5	2	.180	0.000	.180	1.064	.883	446.	-446.	446.	446.	482.	10217.	LBS
245	X AN	2	0.000	0.000	0.000	0.000	484.	0.	0.	0.	0.	0.	482.	LBS
	Y AN	2	0.000	0.000	0.000	0.000	0.	-333.	68.	115.	446.	240.	11341.	LBS
	Z AN	2	0.000	0.000	0.000	0.000	0.	0.	-278.	2278.	-2278.	2286.	240.	LBS
	XM AN	2	0.000	0.000	0.000	0.000	0.	0.	0.	0.	0.	0.	2286.	LBS
	YM AN	2	0.000	0.000	0.000	0.000	0.	0.	0.	0.	0.	0.	0.	LBS
	ZM AN	2	0.000	0.000	0.000	0.000	0.	0.	0.	0.	0.	0.	0.	LBS
252	X AN	2	0.000	0.000	0.000	0.000	768.	1441.	1441.	17140.	-17140.	34471.	-34471.	FTLB
	Y AN	2	0.000	0.000	0.000	0.000	556.	387.	591.	591.	591.	1243.	2093.	FTLB
	Z AN	2	0.000	0.000	0.000	0.000	0.	-236.	0.	0.	0.	0.	0.	LBS
	XM AN	2	0.000	0.000	0.000	0.000	0.	0.	0.	0.	0.	0.	0.	LBS
	YM AN	2	0.000	0.000	0.000	0.000	0.	0.	0.	0.	0.	0.	0.	LBS
	ZM AN	2	0.000	0.000	0.000	0.000	0.	0.	0.	0.	0.	0.	0.	LBS





Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISIO	
REV.	3	1	2
MICROFILMED			
ORIGINATOR	24704 7/12/82		
DATE			

TYPE VERSION G/C4.2  
RUN DATE - 82/06/17.

PIPE THE PUR S/RU DISCHARGE PIPING (ME-91.92) (U.O.-045864000) LLCMO  
FROM SRU(ME-148) TO PRESSURIZER RELIEF TANK

SUPPORT AND LUG DESIGN INFORMATION

NODE NAME	SUPPORT DIR	TYPE	CLS	DESIGN TRAVL	MAX PIPE MOVEMENTS	NORMAL SUST.	EXPAN	OCCAS	EMERGENCY (LUG DSGN LOAD)	REFAULTED (LUG ALLOW STRS)
300	X	AN	2	0.000	0.000	-3.	167.	530.	-530.	674.
301	Y	AN	2	0.000	0.000	-541.	0.	4019.	4019.	4282.
302	Z	AN	2	0.000	0.000	-15.	-299.	1155.	-1155.	1218.
303	X	AN	2	0.000	0.000	379.	0.	2684.	-2684.	3268.
304	Y	AN	2	0.000	0.000	0.	1322.	655.	-655.	891.
305	Z	AN	2	0.000	0.000	12.	0.	1432.	-1432.	1917.
306	X	RR	2	0.000	0.000	6.	0.	928.	-928.	1709.
307	Z	RR	2	0.000	0.000	8.	405.	781.	-781.	1772.
308	Y	DS	2	.513	0.000	.040	.513	2308.	-2308.	2442.
309	X	RR	2	0.000	1.151	0.000	3884.	711.	-711.	6227.
310	Z	RR	2	0.000	1.151	0.000	8.	1032.	-1032.	1040.
311	X	RR	2	0.000	1.248	.091	565.	1719.	-1719.	6370.
312	Y	CS	2	1.224	0.000	1.248	.091	0.	0.	30000.
313	Z	DS	2	.529	0.000	.226	1.791	2286.	-2286.	10752.
314	Y	US	2	.749	0.000	1.010	1.766	3359.	-3359.	2356.
315	X	DS	2	0.000	-.645	.645	.834	672.	0.	13680.
316	Y	US	2	0.000	-.198	.455	.517	900.	0.	10804.
317	Z	DS	2	0.000	-.425	.119	.425	3359.	-3359.	9981.
318	X	RR	2	0.000	.425	0.000	1765.	2627.	-2627.	3798.
319	Z	RR	2	0.000	.425	0.000	0.	786.	0.	11672.
320	X	RR	2	0.000	.149	0.000	39.	5040.	-5040.	897.
321	Z	RR	2	0.000	.149	0.000	45.	527.	-527.	30000.
322	X	RR	2	0.000	.149	0.000	0.	7668.	0.	5092.
323	Z	RR	2	0.000	.149	0.000	0.	1384.	-1384.	10415.
324	Y	RR	2	.295	0.000	.035	-1009.	3218.	-3218.	591.
325	X	AN	2	0.000	0.000	-5.	5204.	3088.	-3088.	22015.
326	Z	AN	2	0.000	0.000	-588.	0.	367.	0.	1433.
327	X	AN	2	0.000	0.000	21.	0.	1138.	-1138.	30000.
328	Z	AN	2	0.000	0.000	52.	267.	1477.	-1477.	5092.
329	X	AN	2	0.000	0.000	69.	0.	6194.	-6194.	10415.
330	Z	AN	2	0.000	0.000	374.	0.	1364.	-1364.	22015.
331	X	AN	2	0.000	0.000	0.	0.	3087.	-3087.	2842.
332	Z	AN	2	0.000	0.000	0.	0.	756.	-756.	30000.
333	X	AN	2	0.000	0.000	0.	0.	2294.	-2294.	10415.
334	Z	AN	2	0.000	0.000	0.	0.	3002.	-3002.	10415.
335	X	AN	2	0.000	0.000	0.	0.	12461.	-12461.	2842.
336	Z	AN	2	0.000	0.000	0.	0.	2842.	-2842.	0.



Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

TRIPLE TMI PUR S/RV DISCHARGE PIPING (ME- 91,92) (U.O.-045064000) LLCHO  
FROM SRV(ME-148) TO PRESSURIZER RELIEF TANK

TRIPLE VERSION 0/C4.2  
RUN DATE- 02/06/17.

SUPPORT AND LUG DESIGN INFORMATION

NODE NAME	SUPPORT DIR	TYP	CLS	DESIGN TRAVLS			MAX PIPE MOVEMENTS			NORMAL SUST.	REBUPSET		EMERGENCY		FAULTED				
				+	-		X	Y	Z		+ EXPAN -	+ OCCAS -	+ OCCAS -	+ OCCAS -	+ OCCAS -	+ OCCAS -			
5332	SX	RR	2				.000	.254	.193	88.	2248.	0.	1814.	-1814.	1814.	-1814.	1965.	-1965.	LBS
333	SX	RR	2				0.000	.111	.132	-9.	-0.	-966.	807.	-807.	881.	-881.	1938.	-1938.	LBS
336	Y	US	2	.173	0.000		.100	.237	.125	-1045.	0.	0.			2913.		30000.		LBS
337	X	DS	2	.318	0.000		.318	.723	.278				3292.	-3292.	3292.	-3292.	6847.	-6847.	LBS
340	SX	DS	2	0.000	-.512		.512	1.114	.245				1331.	-1331.	4767.	-4767.	9626.	-9626.	LBS
5341	Y	DS	2	.954	0.000		.619	.954	.703				2422.	-2422.	2422.	-2422.	3348.	-3348.	LBS
344	Y	CS	2	1.037	0.000		.668	1.214	1.437	-1115.	0.	0.					1115.	-1115.	LBS
5345	SX	DS	2	.182	0.000		.182	1.121	1.395				3316.	-3316.	3316.	-3316.	3976.	-3976.	LBS
348	X	AN	2				0.000	0.000	0.000	-17.	0.	-221.	322.	-322.	3542.	-3542.	3101.	-3101.	LBS
	Y	AN	2				0.000	0.000	0.000	-1125.	0.	-396.	2475.	-2475.	2475.	-2475.	2637.	-2637.	LBS
	Z	AN	2				0.000	0.000	0.000	0.	0.	0.	0.	0.	0.	0.	0.	0.	LBS
	X	AN	2				0.000	0.000	0.000	120.	0.	-739.	1960.	-1960.	28461.	-28461.	56956.	-56956.	FTLB
	Y	AN	2				0.000	0.000	0.000	-37.	0.	-920.	369.	-369.	3052.	-3052.	6115.	-6115.	FTLB
	Z	AN	2				0.000	0.000	0.000	-197.	1055.	0.	937.	-937.	3427.	-3427.	6917.	-6917.	FTLB
356	X	AN	2				0.000	0.000	0.000	4.	312.	0.	804.	-804.	804.	-804.	1284.	-1284.	LBS
	Y	AN	2				0.000	0.000	0.000	-898.	199.	0.	374.	-374.	506.	-506.	1080.	-1080.	LBS
	Z	AN	2				0.000	0.000	0.000	1.	134.	0.	1270.	-1270.	4553.	-4553.	9195.	-9195.	LBS
	X	AN	2				0.000	0.000	0.000	-304.	1076.	0.	1737.	-1737.	7269.	-7269.	14642.	-14642.	FTLB
	Y	AN	2				0.000	0.000	0.000	-14.	0.	-1256.	255.	-255.	422.	-422.	882.	-882.	FTLB
	Z	AN	2				0.000	0.000	0.000	-42.	0.	-357.	1274.	-1274.	1274.	-1274.	2142.	-2142.	FTLB

SUBJECT	REV.	3
	MICROFILMED	
	ORIGINATOR	JK/MS
DATE	7/26/83	
CISID	1	
	2	
	3	
PAGES	9	

PROPRIETARY INFORMATION OF GILBERT ASSOCIATES, INC. - FOR INTERNAL USE ONLY





Gilbert Associates, inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISID			PAGE
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR	D.K.H.				
DATE	7/20/82				

7.2.2 FLUID TRANSIENT FORCING FUNCTION  
FOR TIME HISTORY DYNAMIC ANALYSIS

L. Y. L. Chou G III 2400

memorandum



Gilbert/Commonwealth

to: M. Z. LEE

from: R. Murthy

subject: TMI1 SRVS and PORV Discharge Line Forces -  
Data Transmittal

June 7, 1982

Enclosed are the preliminary force data and plots obtained from the RELAP5/ MOD1 analyses of the TMI-1 SRVS and PORV discharge piping systems. The force data are in the following files:

- 1.0 TMI.PORV.FORCE.PSI70.DATA  
(opening of the PORV with 400°F, 2500 psig subcooled water and 70 psia back pressure).
- 1.1 FORCE plots of Item 1.0 for 0-0.25 sec (Plots for 0.25 - 0.5 sec could not be obtained).
- 2.0 SRV40.DATA  
(opening of SRV with 400°F, 2500 psig subcooled water and 70 psia back pressure).
- 2.1 FORCE plots of Item 2.0
- 3.0 STEAM.DATA  
opening of SRV with 2500 psig steam pressure and 70 psia back pressure.
- 3.1 FORCE plots of Item 3.0

*R. Murthy*  
R. MURTHY

RM:jah

Enclosure

- cc: P. Bunker
- R. E. Anderson *RE Anderson*
- M. Waselus
- G. Kowal
- L. Y. L. Chou
- R. R. Brems



Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				OF
ORIGINATOR <i>EXHIBIT</i>				PAGES
DATE <i>7/50/82</i>				

7.2.3. SEISMIC SPECTRUM ANALYSIS  
INPUT DATA



**Gilbert Associates, Inc.**  
Reading, Pennsylvania  
**CALCULATION**

SUBJECT				CISID			PAGE
REV.	0	1	2	3	OF		
MICROFILMED					PAGES		
ORIGINATOR	R. C. ...						
DATE	2/1/82						

1  
0.01 0.48  
0.02 0.55  
0.025 0.6  
0.028 0.77  
0.032 1.1  
0.037 0.74  
0.042 0.7  
0.048 0.9  
0.056 1.18  
0.062 1.5  
0.07 2.2  
0.076 3.0  
0.078 4.0  
0.08 5.0  
0.084 7.0  
0.09 8.0  
0.1 7.0  
0.105 3.0  
0.11 2.0  
0.12 1.3  
0.13 0.97  
0.15 0.7  
0.2 0.5  
0.33 0.28  
1.0 0.17

25 TMI HORIZ 1 RESPONSE

2  
0.01 0.32  
0.02 0.367  
0.025 0.4  
0.028 0.513  
0.032 0.733  
0.037 0.493  
0.042 0.467  
0.048 0.6  
0.056 0.787  
0.062 1.0  
0.07 1.467  
0.076 2.0  
0.078 2.667  
0.08 3.333  
0.084 4.66  
0.09 5.333  
0.10 4.667  
0.105 2.0  
0.11 1.333  
0.12 0.867  
0.13 0.647  
0.15 0.467  
0.2 0.333  
0.33 0.187  
1.0 0.113

25 TMI VERT RESPONSE

3  
0.01 0.48  
0.02 0.55  
0.025 0.6  
0.028 0.77  
0.032 1.1  
0.037 0.74  
0.042 0.7  
0.048 0.9  
0.056 1.18  
0.062 1.5  
0.07 2.2  
0.076 3.0  
0.078 4.0  
0.08 5.0  
0.084 7.0  
0.09 8.0  
0.1 7.0  
0.105 3.0  
0.11 2.0  
0.12 1.3  
0.13 0.97  
0.15 0.7  
0.2 0.5  
0.33 0.28  
1.0 0.17  
??

25 TMI HORIZ 2 RESPONSE

TMI-1 SEISMIC SPECTRUM DATA  
FROM REACTOR INTER-BUILDING FIG-8



Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				PAGES
ORIGINATOR	K. J. [unclear]			
DATE	7/26/82			

7.2.4 THERMAL MOVEMENT CALCULATION




Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT	CISID			PAGE
REV. 0	1	2	3	1 OF
MICROFILMED				PAGES 2
ORIGINATOR T. W. ...				
DATE ...				

## Simple Calculation of Thermal Expansion Absorbed



Assume:  $\alpha = 7.3 \times 10^{-6} \text{ in/in/}^{\circ}\text{F}$

Given:  $\Delta y = 1 \frac{3}{8} \text{ ''}$

$$\Delta L = 353' 1 \frac{11}{16}'' - 326' = 325.69''$$

Therefore the temperature change can be found as

$$\Delta T = \frac{\Delta y}{\alpha \Delta L} = \frac{1.375}{9.3 \times 10^{-6} \times 325.69} = 454^{\circ}\text{F}$$



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT

CISID

PAGE

2

OF

REV.

0

1

2

3

MICROFILMED

PAGES 2

ORIGINATOR

T. W. C. J.

DATE

6/15/72

Assume linear expansion of the top of the pressure vessel, therefore the total movement, in the radial direction, of each valve site can be calculated as

$$\begin{aligned} \Delta R &= \alpha R \Delta T \\ &= 9.3 \times 10^{-6} \times (1'5") \times (454) \\ &= 0.072 \text{ in.} \end{aligned}$$

Then (a) the movements of valve site #1 are

$$\begin{cases} \Delta X = -0.072 \cos 40^\circ = 0.055" \\ \Delta Y = 1.375" \\ \Delta Z = +0.072 \sin 40^\circ = 0.046" \end{cases}$$

(b) the movements of valve site #2

$$\begin{cases} \Delta X = 0.072 \cos 15^\circ = 0.070" \\ \Delta Y = 1.375" \\ \Delta Z = -0.072 \sin 15^\circ = -0.019" \end{cases}$$

(c) the movements of valve site #3

$$\begin{cases} \Delta X = -0.072 \sin 25^\circ = -0.030" \\ \Delta Y = 1.375" \\ \Delta Z = -0.072 \cos 25^\circ = -0.065" \end{cases}$$

-34-





Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISID		PAGE	
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR <i>Ryker</i>					
DATE <i>7/20/82</i>					



## 8. GEOMETRY PLOTS

SET 1. PORV - ME-162,93

SET 2. SRV1 - ME-88,89

SET 3. SRV2 - ME-91,92

SET 4. SRV REMOVED



PRESSURIZER  
RELIEF VALVE  
PIPING ISO.  
(DOWN STREAM)

T.M.I.




Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT				CISID			PAGE
REV.	0	1	2	3	OF		
MICROFILMED							
ORIGINATOR <i>W. J. GOU</i>							
DATE <i>7/20/82</i>							
PAGES							






Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT				CISID			PAGE
REV.	0	1	2	3	OF		
MICROFILMED							PAGES
ORIGINATOR <i>L. H. H. H.</i>							
DATE <i>7/30/82</i>							






Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT					CISID				PAGE	
REV.	0	1	2	3	OF					
MICROFILMED					PAGES					
ORIGINATOR	<i>Ryngaert</i>									
DATE	<i>7/25/82</i>									








Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT		CISID			PAGE
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR <i>SL/K/04</i>					
DATE <i>7/26/53</i>					

VIEW 1 (N1-SR01)








Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT	CISID			PAGE
REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>L. Gilbert</i>			
DATE	<i>7/20/82</i>			

VIEW E TH1-SK01



*Y  
X  
Z*




Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT	CISID			PAGE
REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>W. J. Kelly</i>			OF
DATE	<i>7/20/82</i>			PAGES

VIEW 4 TH1-SR01






Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISID			PAGE
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR	<i>J. J. [unclear]</i>				
DATE	<i>2/20/82</i>				








Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT				CISID		PAGE	
REV.	0	1	2	3	OF		
MICROFILMED					PAGES		
ORIGINATOR	V. Kony						
DATE	7/20/82						

VIEW 1 TH1






Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT				CISID			PAGE
REV.	0	1	2	3	OF		
MICROFILMED					PAGES		
ORIGINATOR	L. V. G. G. G.						
DATE	7/30/82						





Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT

CISID

PAGE

REV.

0

1

2

3

OF

MICROFILMED

PAGES


ORIGINATOR

*E. V. Gray*

DATE

*7/31/82*

VIEW & TITLE








Gilbert Associates, Inc.


Reading, Pennsylvania

CALCULATION


SUBJECT		CISID			PAGE
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR <i>Zyff</i>					
DATE <i>7/16/82</i>					

VIEW T TRI





RC-RV13



NEW CAD A-  
CUT LINE

PLAN  
(MODIFICATION)



2

REACTOR BLD'G

MK-PR-33

MK-PR-32



RIP-OUT

RC-RV.A

RIP-OUT

RC-RV.B


1/2"



RIP-OUT

PRESSURIZER  
RC-T-2

3.0



35 -

RIP-OUT


PLAN  
(RIP-OUT)

EL 341.8' A

PRESSURIZER VESSEL SHELD

RC-2.1A

RC-2.1B



PRESSURIZER VESSEL

EL 349.3


S

1

SECTION B-B

SEE R/A (SHOWN)  
RECEIVE VIA (S),

FIELD OUT FIG 4 & 6  
TO BE USED IN  
NOISE CATION



SECTION A-A  
(RIP-OUT)



Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	[Handwritten Signature]			
DATE	7/28/82			

9. IDENTIFICATION OF COMPUTER OUTPUT FILES

FILE NO.	JOB I.D.	JOB DATE	FILE NAME	DESCRIPTION
1	AYXBBDI	6/17/82	PORVP	PORV POST PROCESS
2	AYXBANH	6/17/82	PORV	PORV DW, THERMAL, OBE
3	AYXBBAK	6/17/82	PORVTH	PORV TIME HISTORY
4	AYXBMBK	6/16/82	SRV1P	SRV1 POST PROCESS
5	AYXBLTD	6/16/82	SRV1	SRV1 DW, THERMAL, OBE
6	AYXBLYV	6/16/82	SRV1A	SRV1 TIME HISTORY (SUBCOOLED)
7	AYXBAWS	6/16/82	SRV1B	SRV1 TIME HISTORY (STEAM)
8	AYXBADC	6/16/82	SRV2P	SRV2 POST PROCESS
9	AYXDLVO	6/16/82	SRV2	SRV2 DW, THERMAL, OBE
10	AYXBAJZ	6/16/82	SRV2A	SRV2 TIME HISTORY (SUBCOOLED)
11	AYXBAMQ	6/16/82	SRV2B	SRV2 TIME HISTORY (STEAM)
12	AYXBCAU	6/23/82	PORVDW	PORV DEADWEIGHT (STEAM)
13	AYXBCBD	6/23/82	SRV1DW	SRV1 DEADWEIGHT (STEAM)
14	AYXBCAV	6/23/82	SRV2DW	SRV2 DEADWEIGHT (STEAM)
15	T452(A1202)	6/7/82	SRV40.DATA	SRV SUBCOOLED DISCHARGE FORCES
16	T452(A1202)	6/7/82	STEAM.DATA	SRV STEAM DISCHARGE FORCES
17	T452(A1202)	6/7/82	TMI.PORV.FORCE.PSIA70.DATA	

NOTE : SRV1(ME-147,ME-88,89) AND SRV2(ME-148,ME-91,92)



Gilbert Associates, Inc.

Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT				CISID		PAGE
REV.	0	1	2	3	OF	
MICROFILMED						PAGES
ORIGINATOR <i>D. J. G. J.</i>						
DATE <i>8/16/82</i>						

9. IDENTIFICATION OF COMPUTER OUTPUT FILES (Continued)

FILE NO.	JOB I.D.	JOB DATE	FILE NAME	DESCRIPTION
18	AYXBBCO	7/30/82	SRV2P	SRV2 POST PROCESS (ADD ONE SNUBBER)
19	AYXBCHE	7/29/82	SRV2	SRV2 DW, THERMAL, OBE (ADD ONE SNUBBER)
20	AYXBDKQ	7/30/82	SRV2A	SR2 TIME HISTORY (SUB) (ADD ONE SNUBBER)
21	AYXBPB	7/30/82	SRV2B	SRV2 TIME HISTORY (STEAM)
22	AYXBDZM	8/3/82	SRV2TH	SRV2 THERMAL (COLD PIPING)
23	AYXBDZI	8/3/82	SRV1TH	SRV1 (COLD PIPING)





Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT		CISID			PAGE
REV.	0	1	2	3	OF
MICROFILMED					PAGES
ORIGINATOR	L. W. H. H. H.				
DATE	7/30/82				

10. EVALUATION OF PIPE SUPPORT  
AND EQUIPMENT NOZZLE

10.1. EQUIPMENT NOZZLE LOAD SUMMARY

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME- 88,89)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: _____	VERIFIER: _____	PAGE 001 OF 001
	DATE: _____		

2.10 NOZZLE LOAD SUMMARY

EQUIPMENT : SRV TAG NO. : RC-RV1B  
 NOZZLE SIZE : 6" SERVICE : RC JOINT NO. : 249(MEMBER-2520)  
 REFERENCE : PRESSURIZER SAFETY RELIEF VALVE OUTLET FLANGE  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z-SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBLTD )	0.	-249.	0.	0.	0.	1344.
THERMAL (AYXBLTD )	31.	103.	236.	-1800.	12636.	-5976.
SEISMIC-OBE (AYXBLTD )	*2393.	*198.	0.	0.	0.	*1368.
BLOWDOWN (AYXBLYU )	*2035.	*84.	0.	0.	0.	*5126.
DW(NORMAL)# (AYXBCBD )	0.	-87.	0.	0.	0.	120.
THERMAL # (AYXEDZI )	-2.	-216.	230.	-1800.	12636.	12780.
( )						

- NOTE :
1. \* — POSITIVE AND NEGATIVE VALUES
  2. # — PLANT NORMAL OPERATING LOAD

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME- 91,92)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: _____	VERIFIER: _____	PAGE 001 OF 001
	DATE: _____		

2.10 NOZZLE LOAD SUMMARY

EQUIPMENT : SRV TAG NO. : RC-RV1A  
 NOZZLE SIZE : 6" SERVICE : RC JOINT NO. : 353(MEMBER-3560)  
 REFERENCE : PRESSURIZER SAFETY RELIEF VALVE OUTLET FLANGE  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z-SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBCHE )	1.	-174.	-4.	-420.	-132.	-36.
THERMAL (AYXBCHE )	134.	199.	-312.	1872.	-11712.	-8124.
SEISMIC-OBE (AYXBCHE )	*560.	*60.	*60.	*98.	*60.	*1056.
BLOWDOWN (AYXBDKQ )	*991.	*167.	*178.	*1503.	*2685.	*5238.
DW(NORMAL)# (AYXBCAV )	0.	-56.	-2.	-192.	-60.	-492.
THERMAL # (AYXDZMI )	0.	-324.	-122.	2892.	-4716.	14502.
( )						

- NOTE :
1. \* — POSITIVE AND NEGATIVE VALUES
  2. # — PLANT NORMAL OPERATING LOAD

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE 1
	PROJECT NAME Three Mile Island Unit #1	W.D. NUMBER 04-5064-000	PAGE


SUBJECT SUPPORT LOAD SUMMARY SHEET	ORIGINATOR <i>RYCHALL</i>
	DATE <u>8/5/82</u>
	VERIFIER <i>J. C. ...</i>
	DATE <u>3-8-82</u>

MARK NO. PRXX

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 34-6

SEISMIC CATEGORY \_\_\_\_\_



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

(UP) DM 1.0476  
 N (S) 0.0317  
 (E) W 0.3081

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ 349 - 349	+ -	+ -	+ -
SRVZ	+ -	+ -	+ 469 - 469	+ -	+ -	+ -
DESIGN LOAD	+ -	+ -	+ 818 - 818	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ -	+ 1167 - 1167	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3  
and non-nuclear supports

Seismic  
Category

Loading Cases

Condition  
Classification

1&2

- a) Deadweight + Thermal
- b) Deadweight + Thermal + OBE
- c) Deadweight + Thermal ±(2)OBE

- (Normal) Operating
- (Occasional) Design
- (Occasional) Hypothetical

B & Non-Nuclear a) Deadweight + Thermal

(Normal) Operating

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME-162,93)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>L. J. G. U.</i>	VERIFIER:	PAGE 001 OF 001
	DATE: <i>7/20/82</i>		

**2.10 NOZZLE LOAD SUMMARY**

EQUIPMENT : PORV TAG NO. : RC-RV2  
 NOZZLE SIZE : 4" SERVICE : RC JOINT NO. : 143(MEMBER-1450)  
 REFERENCE : PRESSURIZER PORV OUTLET FLANGE  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBANH)	-72.	2.	11.	132.	432.	-864.
THERMAL (AYXBANH)	-33.	64.	-1133.	8124.	300.	276.
SEISMIC-OBE (AYXBANH)	*83.	*164.	*238.	*1452.	*2124.	*3456.
BLOWDOWN (AYXBBAK)	*229.	*304.	*591.	*2138.	*1558.	*2910.

- NOTE :
1. RUN AYXBANH DATED 6/16/82
  2. RUN AYXBBAK DATED 6/17/82
  3. \* — POSITIVE AND NEGATIVE VALUES

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME-102, 23)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>R.K. [unclear]</i>	VERIFIER: _____	PAGE 001 OF 001
	DATE: <i>7/20/82</i>		

**2.10 NOZZLE LOAD SUMMARY**

EQUIPMENT : *PENETRATION* TAG NO. : *PR8*  
 NOZZLE SIZE : *4"* SERVICE : RC JOINT NO. : *129*  
 REFERENCE : *PENETRATION*  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBANH)	-9.	-143.	17.	156.	636.	-636.
THERMAL (AYXBANH)	1734.	411.	-2639.	-5016.	-57888.	-1920.
SEISMIC-OBE (AYXBANH)	±26.	±36.	±294.	±1800.	±17820.	±1680.
BLOWDOWN (AYXBBAK)	±591.	±93.	±242.	±782.	±5086.	±2760.
NORMAL (_____)						
UPSET (_____)						
EMERGENCY (_____)						
FAULTED (_____)						

- NOTE :
1. RUN AYXBANH DATED 6/16/82
  2. RUN AYXBBAK DATED 6/17/82

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME-16243)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>L. K. Hall</i>	VERIFIER:	PAGE 001 OF 001
	DATE: <i>7/2/84</i>		

2.10 NOZZLE LOAD SUMMARY

EQUIPMENT : *DRAIN TANK* TAG NO. : *WDL-T-3*  
 NOZZLE SIZE : *10"* SERVICE : RC JOINT NO. : *H100(MEMBER-1000)*  
 REFERENCE : PRESSURIZER RELIEF DRAIN TANK  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBANH)	-389.	-1.	-15.	12.	-3132.	-36.
THERMAL (AYXBANH)	-378.	91.	-84.	-12.	684.	4080.
SEISMIC-OBE (AYXBANH)	±52.	±20.	±43.	±624.	±2328.	±840.
BLOWDOWN (AYXBAK)	±262.	±31.	±68.	±770.	±3618.	±1765.
NORMAL ( )						
UPSET ( )						
EMERGENCY ( )						
FAULTED ( )						

NOTE :

1. RUN AYXBANH DATED 6/16/82
2. RUN AYXBAK DATED 6/17/82



GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME- 88,89)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>[Signature]</i> DATE: <i>7/29/82</i>	VERIFIER: _____ _____	PAGE 001 OF 001

2.10 NOZZLE LOAD SUMMARY

EQUIPMENT : SRV TAG NO. : RC-RV1B  
 NOZZLE SIZE : 6" SERVICE : RC JOINT NO. : 249(MEMBER-2520)  
 REFERENCE : PRESSURIZER SRV OUTLET FLANGE  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBLTD )	0.	-249.	0.	0.	0.	1344.
THERMAL (AYXBLTD )	31.	103.	236.	-1800.	12636.	-5976.
SEISMIC-OBE (AYXBLTD )	*2393.	*198.	0.	0.	0.	*1368.
BLOWDOWN (AYXBLYU )	*2035.	*84.	0.	00.	0.	*5126.

NOTE :

1. RUN AYXBLTD DATED 6/16/82
2. RUN AYXBLYU DATED 6/17/82
3. \* — POSITIVE AND NEGATIVE VALUES



GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME-88.87)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>[Signature]</i>	VERIFIER:	PAGE 001 OF 001
	DATE: <i>2/2/82</i>		

**2.10 NOZZLE LOAD SUMMARY**

EQUIPMENT : *PENETRATION* TAG NO. : *PR7*  
 NOZZLE SIZE : *6"* SERVICE : RC JOINT NO. : *227*  
 REFERENCE : *PENETRATION*  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXB <del>LTD</del> )	-157.	-276.	377.	6204.	9864.	7368.
THERMAL (AYXB <del>LTD</del> )	2669.	-879.	-5032.	-4464.	-92184.	-55980.
SEISMIC-OBE (AYXB <del>LTD</del> )	±167.	±567.	±1307.	±29748.	±66564	±27516.
BLOWDOWN (AYXB <del>LYU</del> )	±2162.	±1147.	±1053.	±15327.	±41872.	±22341.
NORMAL ( <del>      </del> )						
UPSET ( <del>      </del> )						
EMERGENCY ( <del>      </del> )						
FAULTED ( <del>      </del> )						

NOTE :  
 1. RUN AYXB~~LTD~~ DATED 6/16/82  
 2. RUN AYXB~~LYU~~ DATED 6/17/82

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME-2357)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <u>X/Goul</u>	VERIFIER:	PAGE 001 OF 001
	DATE: <u>7/26/82</u>		

2.10 NOZZLE LOAD SUMMARY

EQUIPMENT : REACTOR COOLANT TANK TAG NO. : WDL-T-3  
 NOZZLE SIZE : 10" SERVICE : RC JOINT NO. : H200 (MEMBER-2000)  
 REFERENCE : REACTOR COOLANT DRAIN TANK  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBLTD)	-1730.	-2.	1	-36	-48	-108.
THERMAL (AYXBLTD)	-534.	+208.	56.	6132.	-2832.	10464.
SEISMIC-OBE (AYXBLTD)	±272.	±7.	±44.	±912.	±2232.	±360.
BLOWDOWN (AYXBLWB)	±2937.	±46.	±35.	±344.	±1305.	±194.
NORMAL ( )						
UPSET ( )						
EMERGENCY ( )						
FAULTED ( )						

- NOTE :
1. RUN AYXBLTD DATED 6/16/82
  2. RUN AYXBLWB DATED 6/17/82

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME- 91,92)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>L. K. O'Connell</i>	VERIFIER: _____	PAGE 001 OF 001
	DATE: <i>7/20/82</i>	_____	

2.10 NOZZLE LOAD SUMMARY

EQUIPMENT : SRV TAG NO. : RC-RV1A  
 NOZZLE SIZE : 6" SERVICE : RC JOINT NO. : 353(MEMBER-3560)  
 REFERENCE : PRESSURIZER SRV OUTLET FLANGE  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBLVO )	1.	-174.	-4.	-420.	-132.	-36.
THERMAL (AYXBLVO )	134.	199.	-312.	1872.	-11712.	-8124.
SEISMIC-OBE (AYXBLVO )	*4401.	*473.	*477.	*456.	*192.	*8112.
BLOWDOWN (AYXBLJZ )	*991.	*161.	*176.	*127.	*229.	*5206.

NOTE :

1. RUN AYXBLTD DATED 6/16/82
2. RUN AYXBLYU DATED 6/17/82
3. \* — POSITIVE AND NEGATIVE VALUES

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5004-000	FILING CODE (ME-5/1,72)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>Zygaru</i>	VERIFIER:	PAGE 001 OF 001
	DATE: <i>7/21/82</i>		

**2.10 NOZZLE LOAD SUMMARY**

EQUIPMENT : *PENETRATION* TAG NO. : *FR 7*  
 NOZZLE SIZE : " SERVICE : RC JOINT NO. : *32*  
 REFERENCE : *PENETRATION*  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBLV0)	-5.	-541.	-15.	4548.	36.	144.
THERMAL (AYXBLV0)	5204.	-1210.	-881.	3204.	-94788.	-109860.
SEISMIC-OBE (AYXBLV0)	±346.	±367.	±1138.	±17724.	±74378.	±16362.
BLOWDOWN (AYXBLTZ)	±3008.	±180.	±192.	±6160.	±8256.	±9607.
NORMAL ( )						
UPSET ( )						
EMERGENCY ( )						
FAULTED ( )						

- NOTE :
1. RUN AYXBLV0 DATED 6/16/82
  2. RUN AYXBLTZ DATED 6/17/82

GILBERT ASSOCIATES, INC. READING, PA.	TMI UNIT-1 NUCLEAR STATION	W.O. NUMBER 04-5064-000	FILING CODE (ME-7/1,72)
PIPING ENGINEERING DEPT. NUMBER 0432	ORIGINATOR: <i>X. K. ...</i>	VERIFIER:	PAGE 001 OF 001
	DATE: <i>5/20/82</i>		

2.10 NOZZLE LOAD SUMMARY

EQUIPMENT : *TANK* TAG NO. : *LDL-T-3*  
 NOZZLE SIZE : *10"* SERVICE : RC JOINT NO. : *H300MEMBER-3000*  
 REFERENCE : *REACTOR COOLANT DRAIN TANK*  
 ORIENTATION : LOCAL (X - AXIAL, Y,Z - SHEAR)

LOAD CASE (RUN I.D.)	FORCES (LBS)			MOMENTS (IN-LBS)		
	FX	FY	FZ	MX	MY	MZ
DEADWEIGHT (AYXBLVD)	-541.	-3	15.	36.	4548.	-144.
THERMAL (AYXBLVD)	-243.	167.	299.	15864.	-15396.	4944.
SEISMIC-OBE (AYXBLVD)	±740.	±208.	±194.	±3624.	±11184.	±7644.
BLOWDOWN (AYXBLJZ)	±4019.	±530.	±1155.	±7857.	±32211.	±17187.
NORMAL ( — )						
UPSET ( — )						
EMERGENCY ( — )						
FAULTED ( — )						

NOTE :

1. RUN AYXBLVD DATED 6/16/82
2. RUN AYXBLJZ DATED 6/17/82



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT				CISID				PAGE	
REV.	0	1	2	3	OF				
MICROFILMED					PAGES				
ORIGINATOR	L. J. LEON								
DATE	7/20/82								

10.3 SUPPORT LOAD DETAILS

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-5064-000	PAGE
SUBJECT Support Load Summary Sheet <i>A</i>			ORIGINATOR <i>[Signature]</i>
MARK NO. <i>RC 5-1-10</i>			DATE <i>[Blank]</i>
TYPE OF SUPPORT _____			VERIFIER _____
ANALYSIS CODE _____			DATE <i>[Blank]</i>
ANALYSIS JOINT NO. <i>E100</i>			_____

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
DEADWEIGHT	1 ( )	-1.	-37.	+15.	-3132.	+12.	+56.
	2 ( )						
	3 ( )						
THERMAL	1 ( )	+11.	-378.	+24.	+654.	-12.	-4080.
	2 ( )						
	3 ( )						
SEISMIC - OBE	1 ( )	±20.	±52.	±43.	±2328.	±624.	±640.
	2 ( )						
	3 ( )						
<i>PORV</i>	1 ( )	+18.	+262.	+64.	+3618.	+526.	+1265.
	2 ( )	-31.	-108.	-68.	-1354.	-770.	-710.
	3 ( )						
DESIGN LOAD		+129.	+514.	+206.	+6650.	+1162.	+2141.
		-52.	-927.	-111.	-5514.	-1406.	-5630.
HYPOTHETICAL LOAD		+149.	+566.	+227.	+6958.	+1726.	+2481.
		-72.	-479.	-154.	-9142.	-2030.	-6470.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1 & 2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal ± (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE




GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR30  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 102  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
 DATE \_\_\_\_\_  
 VERIFIER  
 DATE 6-17-82



(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)  
 (UP) DN .5346  
 N S \_\_\_\_\_  
 E W \_\_\_\_\_

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 2. -	+	+ - 15.	+	+	+
THERMAL	+ - 208.	+	+ - 83.	+	+	+
SEISMIC-OBE	+ 83. - 83.	+	+ 165. - 165.	+	+	+
PORV	+ 125. - 67.	+	+ 91. - 74.	+	+	+
DESIGN LOAD	+ 210. - 358.	+	+ 256. - 337.	+	+	+
HYPOTHETICAL LOAD	+ 293. - 441.	+	+ 421. - 502.	+	+	+

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE




GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR46  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 103  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
R. Clark  
 DATE \_\_\_\_\_  
 VERIFIER  
C. Clark  
 DATE 11-7-72

PREDICTED PIPE MOVEMENT (INCHES)  
 UP DN 0.1412 (7)  
 N S 0.6562 (8)  
 E W 0.5271 (8)



NON-GLOBAL

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 120.	+ -	+ -	+ -	+ -	+ -
PORV	+ 77. - 213.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 197 - 333.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 317. - 453.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. J. ...

MARK NO. PR31

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 104

SEISMIC CATEGORY \_\_\_\_\_

DATE: \_\_\_\_\_

VERIFIER: C. W. ...


DATE: 2-17-82

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 1.4877

N S \_\_\_\_\_

E W \_\_\_\_\_



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 136.	+ -	+ 2. -	+ -	+ -	+ -
THERMAL	+ 1331. -	+ -	+ - 281.	+ -	+ -	+ -
SEISMIC-OBE	+ - 416.	+ -	+ - 119.	+ -	+ -	+ -
PORV	+ 168. - 142.	+ -	+ 50. - 172.	+ -	+ -	+ -
DESIGN LOAD	+ 1915. - 694.	+ -	+ 171. - 572.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2331. - 1110.	+ -	+ 290. - 691.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR22  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 107  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER C.H. [unclear]  
 DATE \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)  
 UP/DN 1.6436  
 N S \_\_\_\_\_  
 E W 0.0376



	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 135. -	+ - 25/.	+ -	+ -	+ -	+ -
THERMAL	+ - 1436.	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ 455. -	+ -	+ -	+ -	+ -	+ -
<i>PORV</i>	+ 106. - 344.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 696. - 2235.	+ - 25/.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 1151. - 2690.	+ - 25/.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Cases</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal b) Deadweight + Thermal + OBE c) Deadweight + Thermal + (2) OBE	(Normal) Operating (Occasional) Design (Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR17  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 112  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
R. J. [Signature]  
 DATE \_\_\_\_\_  
 VERIFIER  
[Signature]  
 DATE 5/17/72

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.5085  
 N S 0.2968  
 E W 0.2704



RIGHT HAND CARTESIAN  
 COORDINATE SYSTEM  
 (ANALYST TO DEFINE)  
 NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	- 113.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
<u>PCRV</u>	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	- 113.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	- 113.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating


FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR50  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. S113  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER \_\_\_\_\_  
 DATE \_\_\_\_\_



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)  
 UP/DN 0.9842  
 N S 0.0348  
 E W 2.5001

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 123.	+ -	+ -	+ -	+ -	+ -
PCRV	+ 316. - 39.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 439. - 162	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 562. - 285.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK14  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 116  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER \_\_\_\_\_  
 DATE \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.1250  
 N S 0.0171  
 E W 0.2663



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
DEADWEIGHT	+	+	+	+	+	+
	-	- 150.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
<i>PORV</i>	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	- 150.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	- 150.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category

Loading Cases

Condition Classification

1&2	a) Deadweight + Thermal b) Deadweight + Thermal + OBE c) Deadweight + Thermal + (2)OBE	(Normal) Operating (Occasional) Design (Occasional) Hypothetical
-----	--	--

3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating
-----------------	-------------------------	--------------------



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. FK-7

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 117

SEISMIC CATEGORY \_\_\_\_\_

DATE: \_\_\_\_\_

VERIFIER: C. BLIN


DATE: 6-17-72

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.5502

(N) S 0.0535

(E) W 0.0253



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ - 84.	+ -	+ -	+ -	+ -
PCR V	+ -	+ - 103.	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 187.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 271.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK-1

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 120

SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_

DATE 7-82

VERIFIER C. K. W.


DATE 6-17-82

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.527

N S \_\_\_\_\_

E W \_\_\_\_\_



(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 6.	+ -	+ - 2.	+ -	+ -	+ -
THERMAL	+ 597. -	+ -	+ - 802.	+ -	+ -	+ -
SEISMIC-OBE	+ 42. -	+ -	+ 100. -	+ -	+ -	+ -
PORV	+ 75. - 77	+ -	+ 587. - 127.	+ -	+ -	+ -
DESIGN LOAD	+ 714. - 125.	+ -	+ 639. - 1031.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 756. - 167.	+ -	+ 739. - 1131.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE




GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR27  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 121  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER \_\_\_\_\_  
 DATE 5/17/82

PREDICTED PIPE MOVEMENT (INCHES)  
 UP DN 0.2356  
 N S \_\_\_\_\_  
 E W \_\_\_\_\_



	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+15. -	+	+ -16.	+	+	+
THERMAL	+ -2211.	+	+3650. -	+	+	+
SEISMIC-OBE	+79. -	+	+86. -	+	+	+
<i>PcRV</i>	+115. -107.	+	+118. -275.	+	+	+
DESIGN LOAD	+209. -2397.	+	+3854. -377.	+	+	+
HYPOTHETICAL LOAD	+288. -2476.	+	+3940. -463.	+	+	+

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR11  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 124  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
N. J.  
 DATE \_\_\_\_\_  
 VERIFIER  
C. B. J.  
 DATE 6-17-72

PREDICTED PIPE MOVEMENT (INCHES)

UP DN) 0.0403  
 N S) 0.2771  
 E W) 0.1643



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	- 303.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	- 303.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	- 303.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING  
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company PROJECT NAME Three Mile Island Unit #1	DEPT. NO. 0432	FILING CODE PAGE
SUBJECT Support Load Summary Sheet <span style="float:right">A</span>		ORIGINATOR _____ DATE _____ VERIFIER _____ DATE _____	
MARK NO. <u>FWP</u>		ANALYSIS JOINT NO. <u>129</u>	
TYPE OF SUPPORT _____		ANALYSIS CODE _____	

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
DEADWEIGHT	1( ) 2( ) 3( )	-9.	-148.	+17.	+156.	+636.	-636.
THERMAL	1( ) 2( ) 3( )	+1734.	+411.	-2639.	-5016.	-5788.	-1920.
SEISMIC - OBE	1( ) 2( ) 3( )	+26.	+36.	+294.	+1800.	+17820.	+1680.
POKV	1( ) 2( ) 3( )	+591.	-90.	-57.	+315.	+1403.	+2760.
		-30.	-62.	-542.	-782.	-5126.	-1547.
DESIGN LOAD		+2351. -65.	+540. -241.	+368. -3175.	+2271. -7598.	+19859. -80794.	+4440. -5713.
HYPOTHETICAL LOAD		+2377. -91.	+576. -277.	+662. -3469.	+4071. -9298.	+37679. -98614.	+6120. -7463.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR:                     

MARK NO. PR-6A

ANALYSIS CODE                     

ANALYSIS JOINT NO. 132

SEISMIC CATEGORY                     

DATE                     

VERIFIER                     


DATE                     

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 6.6593

N S                     

E W                     



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 15.	+ -	+ 7. -	+ -	+ -	+ -
THERMAL	+ 185. -	+ -	+ 641. -	+ -	+ -	+ -
SEISMIC-OBE	+ 113. -	+ -	+ 189. -	+ -	+ -	+ -
PCRV	+ 114. - 114.	+ -	+ 71. - 109.	+ -	+ -	+ -
DESIGN LOAD	+ 412. - 242.	+ -	+ 908. - 298.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 525. - 355.	+ -	+ 1097. - 487.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal ±(2)OBE	(Occasional) Hypothetical
B & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating


FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W. O. NUMBER 04-5064-000	PAGE

SUBJECT SUPPORT LOAD SUMMARY SHEET

ORIGINATOR \_\_\_\_\_  
DATE \_\_\_\_\_  
VERIFIER \_\_\_\_\_  
DATE \_\_\_\_\_

MARK NO. PR48  
ANALYSIS CODE \_\_\_\_\_  
ANALYSIS JOINT NO. 5133  
SEISMIC CATEGORY \_\_\_\_\_



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN	<u>1.0326</u>
N/S	<u>0.0346</u>
E/W	<u>0.0410</u>

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ - 205.	+ -	+ -	+ -	+ -
PORV	+ -	+ - 140.	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 1323. - 345.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 550.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR  
DATE  
VERIFIER  
C. K. W.  
DATE 6-17-82

MARK NO. PR6  
ANALYSIS CODE \_\_\_\_\_  
ANALYSIS JOINT NO. 134  
SEISMIC CATEGORY \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)  
UP/DN 1.0342  
N S \_\_\_\_\_  
E W \_\_\_\_\_



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+16. -	+	+4. -	+	+	+
THERMAL	+ -21.	+	+ -1703.	+	+	+
SEISMIC-OBE	+ -195.	+	+ -338.	+	+	+
PCRV	+222. -184.	+	+265. -289.	+	+	+
DESIGN LOAD	+433. -400.	+	+607. -2330.	+	+	+
HYPOTHETICAL LOAD	+628. -595.	+	+745. -2668.	+	+	+

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR5  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 127  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER \_\_\_\_\_  
 DATE \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.2998  
 N S 0.0432  
 E W 6.2537



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	- 517.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	- 517.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	- 517.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE




GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W. O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK47  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 1&2  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER \_\_\_\_\_  
 DATE \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)  
 UP DN 1.4903 (7)  
 N S 0.0219 (8)  
 E W 0.3159 (3)



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

*NON-GLOBAL*

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
THERMAL	+	+	+	+	+	+
SEISMIC-OBE	+ 300.	+	+	+	+	+
<i>PORV</i>	+ 445. - 281.	+	+	+	+	+
DESIGN LOAD	+ 745. - 581.	+	+	+	+	+
HYPOTHETICAL LOAD	+ 1045. - 881.	+	+	+	+	+

Design loading combinations for seismic category 1, 2, 3  
and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

STATUS:  PRELIMINARY  FINAL

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT Support Load Summary Sheet <u>4</u>	ORIGINATOR <u>R. Ch...</u>
MARK NO. <u>Pres. Noyle</u>	DATE <u>3-7-73</u>
TYPE OF SUPPORT _____	VERIFIER <u>...</u>
ANALYSIS CODE _____	DATE <u>3-7-73</u>
ANALYSIS JOINT NO. _____	<u>146</u>

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	1( ) 2( ) 3( )	-2.	-124.	-11.	-804.	+132.	-10728.
THERMAL	1( ) 2( ) 3( )	-67.	-33.	+1135.	+37080.	+8124.	+1824.
SEISMIC - OBE	1( ) 2( ) 3( )	±620.	±624.	±985.	±19704.	±10788.	±25452.
PORV	1( ) 2( ) 3( )	+529. -579.	+423. -425.	+628. -926.	+16160. -24376.	+6728. -7207.	+22727. -21541.
DESIGN LOAD		+1149. -1265.	+1057. -2006.	+2746. -1922.	+72944. -44884.	+25772. -17995.	+50008. -57721.
HYPOTHETICAL LOAD		+1769. -1885.	+1681. -2630.	+3731. -2907.	+92648. -64588.	+36560. -28783.	+75455. -83173.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

Seismic Category	Loading Case	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company PROJECT NAME Three Mile Island Unit #1	DEPT. NO. 0432	FILING CODE PAGE
SUBJECT Support Load Summary Sheet <span style="float:right">A</span>		W.O. NUMBER 04-5064-000	
MARK NO. <u>RC 2001 TANK</u>		ORIGINATOR <u>RC</u>	
TYPE OF SUPPORT _____		DATE <u>6-17-82</u>	
ANALYSIS CODE _____		VERIFIER <u>C. MOORE</u>	
ANALYSIS JOINT NO. <u>H200</u>		DATE <u>6-17-82</u>	

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
DEADWEIGHT	1 ( )	-2.	-1750.	-1.	-48.	-36.	+109.
	2 ( )						
	3 ( )						
THERMAL	1 ( )	+208.	-534.	-56.	-2582.	+61.	-242.
	2 ( )						
	3 ( )						
SEISMIC - OBE	1 ( )	± 7.	± 272.	± 44.	± 2352.	± 112.	± 260.
	2 ( )						
	3 ( )						
SRV1	1 ( )	+3.	+3927.	+28.	+1173.	+344.	+174.
	2 ( )	-5.	-846.	-35.	-1305.	-258.	-151.
	3 ( )						
DESIGN LOAD		+ 218.	+ 3209.	+ 72.	+ 3405.	+ 7358.	+ 662.
		- 14.	- 5322.	- 136.	- 6417.	- 1200.	- 10957.
HYPOTHETICAL LOAD		+ 225.	+ 3481.	+ 116.	+ 5637.	+ 8300.	+ 1022.
		- 21.	- 3654.	- 180.	- 2649.	- 2118.	- 11517.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: K. [Signature]

MARK NO. PR29

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 200

SEISMIC CATEGORY \_\_\_\_\_

DATE: 12-82

VERIFIER: [Signature]

DATE: 12-82



(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.4566

N S \_\_\_\_\_

E W \_\_\_\_\_

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 5. -	+	+ 2. -	+	+	+
THERMAL	+ - 47.	+	+ 132. -	+	+	+
SEISMIC-OBE	+ 16. -	+	+ 104. -	+	+	+
SRVI	+ 8. - 5.	+	+ 54. - 50.	+	+	+
DESIGN LOAD	+ 29. - 510	+	+ 292. - 154.	+	+	+
HYPOTHETICAL LOAD	+ 45. - 526.	+	+ 396. - 258.	+	+	+

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR31  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 201  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER C. [unclear]  
 DATE 2-17-82

PREDICTED PIPE MOVEMENT (INCHES)  
 UP/DN 1.2260  
 N S \_\_\_\_\_  
 E W \_\_\_\_\_



	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 259.	+ -	+ -	+ -	+ -	+ -
THERMAL	+ 3488. -	+ -	+ - 199.	+ -	+ -	+ -
SEISMIC-OBE	+ 722. -	+ -	+ 20. -	+ -	+ -	+ -
SRVI	+ 282. - 398.	+ -	+ 455. - 404.	+ -	+ -	+ -
DESIGN LOAD	+ 4552. - 1439.	+ -	+ 475. - 623.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 5334. - 2221.	+ -	+ 495. - 643.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. C. ...

MARK NO. PA-21

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 204

SEISMIC CATEGORY \_\_\_\_\_

DATE: 11/12

VERIFIER: C. ...


DATE: 11/12

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.3455

N S \_\_\_\_\_

E W 0.0342



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 257. -	+ - 567.	+ -	+ -	+ -	+ -
THERMAL	+ - 3446.	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ 762. -	+ -	+ -	+ -	+ -	+ -
SRVI	+ 627. - 1733.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 1647. - 5941.	+ 0 - 567.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2459. - 6703.	+ 0 - 567.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal ±(2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR  
*R. J. ...*

DATE *11-...*

VERIFIER  
*C. ...*


DATE *...*

MARK NO. PK43

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 5206

SEISMIC CATEGORY \_\_\_\_\_



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 1.5734

N/S 0.2818

E/W 0.1534

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ - 186.	+ -	+ -	+ -
SRVI	+ -	+ -	+ - 892. - 1525.	+ -	+ -	+ -
DESIGN LOAD	+ -	+ -	+ - 1078. - 1711.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ -	+ - 1264. - 1897.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category

Loading Cases

Condition Classification

1&2

- a) Deadweight + Thermal
- b) Deadweight + Thermal + OBE
- c) Deadweight + Thermal + (2)OBE

- (Normal) Operating
- (Occasional) Design
- (Occasional) Hypothetical

B & Non-Nuclear a) Deadweight + Thermal

(Normal) Operating



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR19  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 207  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE 5-17-52  
 VERIFIER C. B. ...  
 DATE 5-17-52

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.464  
 N S 0.2810  
 E W 0.0284



(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	-520.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	-520.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	-520.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR16  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 210  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
R. [unclear]  
 DATE 5/17/82  
 VERIFIER  
C. [unclear]  
 DATE 6/17/82

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.9880  
 N S 0.4042  
 E W 0.3025



RIGHT HAND CARTESIAN  
 COORDINATE SYSTEM  
 (ANALYST TO DEFINE)  
 NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	-523.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	-523.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	-523.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. [Signature]

MARK NO. PK41

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 211

SEISMIC CATEGORY \_\_\_\_\_

DATE 6/17/72

VERIFIER C. [Signature]


DATE 6-17-72

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.4377

(N) S 0.2173

(E) W 0.5073



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 119.	+ -	+ -	+ -	+ -	+ -
SRV1	+ 2640. - 855.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 2759. - 974.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2878. - 1093.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal $\pm$ (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating


FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK13  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 214  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
K. G. ...  
 DATE 17 ...  
 VERIFIER  
C. ...  
 DATE \_\_\_\_\_



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN	<u>0.2596</u>
N S	<u>0.1249</u>
E W	<u>0.4835</u>

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	- 612.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	- 612.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	- 612.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating


FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK 31  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 215  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
 DATE 3/7/82  
 VERIFIER  
 DATE 3/7/82



RIGHT HAND CARTESIAN  
 COORDINATE SYSTEM  
 (ANALYST TO DEFINE)  
 NORTH

PREDICTED PIPE MOVEMENT (INCHES)  
 UP DN 0.5150  
 N S 0.0473  
 E W 0.0545

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ - 556.	+ -	+ -	+ -	+ -
SRV1	+ -	+ - 3805. - 2932.	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 4361. - 3488.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 4917. - 4044.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR28  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 218  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE 7-2  
 VERIFIER \_\_\_\_\_  
 DATE \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)  
 UP DN 0.552  
 N S \_\_\_\_\_  
 E W \_\_\_\_\_



(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 61.	+ -	+ 4. -	+ -	+ -	+ -
THERMAL	+ 817. -	+ -	+ - 2021.	+ -	+ -	+ -
SEISMIC-OBE	+ 25. -	+ -	+ 918. -	+ -	+ -	+ -
SRVI	+ 1480. - 1392.	+ -	+ 6213. - 3746.	+ -	+ -	+ -
DESIGN LOAD	+ 2382. - 1538.	+ -	+ 7135. - 6625.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2467. - 1623.	+ -	+ 8053. - 7623.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category

Loading Cases

Condition Classification

1&2

- a) Deadweight + Thermal
- b) Deadweight + Thermal + OBE
- c) Deadweight + Thermal  $\pm$ (2)OBE

- (Normal) Operating
- (Occasional) Design
- (Occasional) Hypothetical

B & Non-Nuclear a) Deadweight + Thermal

(Normal) Operating



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. PK27

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 219

SEISMIC CATEGORY \_\_\_\_\_

DATE 7/2

VERIFIER C. [unclear]


DATE 7/2

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.2304

N S \_\_\_\_\_

E W \_\_\_\_\_



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 218. -	+	+ - 382.	+	+	+
THERMAL	+ - 3699.	+	+ 7146. -	+	+	+
SEISMIC-OBE	+ - 186.	+	+ 166. -	+	+	+
SRV1	+ 848. - 1205.	+	+ 1164. - 1543.	+	+	+
DESIGN LOAD	+ 1.16. - 5634.	+	+ 8176. - 2091.	+	+	+
HYPOTHETICAL LOAD	+ 1426. - 5264.	+	+ 8642. - 2257.	+	+	+

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. C. ...

MARK NO. FR10

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 222

SEISMIC CATEGORY \_\_\_\_\_

DATE: 5/17/72

VERIFIER: C. ...

DATE: 5/17/72



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

PREDICTED PIPE MOVEMENT (INCHES)

- UP/DN 0.0471
- N/S 0.1806
- E/W 0.0527

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	-1467.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	-1467.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	-1467.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company PROJECT NAME Three Mile Island Unit #1	DEPT. NO. 0432	FILING CODE PAGE W.O. NUMBER 04-5064-000
SUBJECT Support Load Summary Sheet <span style="float:right">4</span>		ORIGINATOR <i>R. J. ...</i>	
MARK NO. <u>PR7</u>		DATE <u>1-7-72</u>	
TYPE OF SUPPORT _____		VERIFIER <i>C. ...</i>	
ANALYSIS CODE _____		ANALYSIS JOINT NO. <u>1-7</u>	

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	1 ( ) 2 ( ) 3 ( )	-157.	-276.	+377.	+6204.	+9864.	-7368.
THERMAL	1 ( ) 2 ( ) 3 ( )	+2667.	-879.	-5032.	-4464.	-92124.	-55920.
SEISMIC - OBE	1 ( ) 2 ( ) 3 ( )	±167.	±567.	±1307.	±29748.	±66567.	±27516.
SXVI	1 ( ) 2 ( ) 3 ( )	+2162.	+1147.	+1053.	+15327.	+41272.	+22341.
		-613.	-941.	-1062.	-16941.	-38376.	-11025.
DESIGN LOAD		+4926.	+1714	+2737.	+51279.	+112000.	+49857.
		-937.	-2663.	-7407.	-51153.	-192124.	-121229.
HYPOTHETICAL LOAD		+5165.	+2221.	+4044.	+21027.	+184861.	+77373.
		-1104.	-3230.	-2714.	-80901.	-250688.	-149405.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating


FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK4A STRUT  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. S230  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
[Signature]  
 DATE 1/17/72  
 VERIFIER  
[Signature]  
 DATE 2/1/72



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)  
 UP DN 0.2023 ( $\bar{Y}$ )  
 N S \_\_\_\_\_  
 E W 0.0753 ( $\bar{Z}$ )

*NON-NUCLEAR*

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 56. -	+	+	+	+	+
THERMAL	+ 1667. -	+	+	+	+	+
SEISMIC-OBE	+ 351. -	+	+	+	+	+
<i>SRVI</i>	+ 1658. - 1438.	+	+	+	+	+
DESIGN LOAD	+ 3732. - 1789.	+	+	+	+	+
HYPOTHETICAL LOAD	+ 4083. - 2140.	+	+	+	+	+

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT SUPPORT LOAD SUMMARY SHEET	ORIGINATOR <i>R. J. ...</i>
---------------------------------------	--------------------------------

MARK NO. PR4  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 233  
 SEISMIC CATEGORY \_\_\_\_\_

DATE 6-17-82  
 VERIFIER  
C. E. ...  
 DATE 6-17-82

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.1942  
 N S) 0.1344  
 E W 0.1468



RIGHT HAND CARTESIAN  
 COORDINATE SYSTEM  
 (ANALYST TO DEFINE)  
 NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ - 1008.	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 1008.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 1008.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Cases</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: *R. [unclear]*

MARK NO. FA37

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 234

SEISMIC CATEGORY \_\_\_\_\_

DATE 6/7/72

VERIFIER \_\_\_\_\_

DATE 6/7/72



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.5720

N S 0.2978

E W 0.2307

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ 260. -	+ -	+ -	+ -	+ -	+ -
SRV1	+ 4318. - 1990.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 4578. - 2256.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 4232. - 2510.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR:         

MARK NO. PK26

ANALYSIS CODE         


ANALYSIS JOINT NO. 237

SEISMIC CATEGORY         

DATE 6/17/72

VERIFIER         

DATE         



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN	<u>1.0241</u>
N/S	<u>0.4957</u>
E/W	<u>0.3180</u>

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ - 871.	+ -	+ -	+ -
SRV1	+ -	+ -	+ 1458. - 2039.	+ -	+ -	+ -
DESIGN LOAD	+ -	+ -	+ 2329. - 2910.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ -	+ 3200. - 3781.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2'	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. [Signature]

MARK NO. PS 24

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 230

SEISMIC CATEGORY \_\_\_\_\_

DATE 2-17-82

VERIFIER C. [Signature]


DATE 6-17-82

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.0478

N S 0.4659

E W 0.3255



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ - 118.	+ -	+ -	+ -	+ -
SRVI	+ -	+ 1424. - 473.	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ 1542. - 591.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ 1660. - 709.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. PK1 SPRING

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 241

SEISMIC CATEGORY \_\_\_\_\_

DATE 6-17-72

VERIFIER C. D. W.

DATE 6-17-72



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP. DN 1.0948

N 0.3349

ⓔ W 0.3446

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ - 1046.	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ -	+ -	+ -	+ -
<u>SRV1</u>	+ -	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 1046.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 1046.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT NO 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. J. ...

MARK NO. PR35

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 242

SEISMIC CATEGORY \_\_\_\_\_

DATE 6/17/82

VERIFIER C. H. ...

DATE 6-17-82



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.045

N S 0.1796

E W 0.3469

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ 92. -	+ -	+ -	+ -	+ -	+ -
SRVI	+ 283. - 446.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 375 - 538.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 467. - 630.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
B & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR:                     

MARK NO. PR23

ANALYSIS CODE                     

ANALYSIS JOINT NO. 245

SEISMIC CATEGORY                     

DATE 6-17-82

VERIFIER C. NEW


DATE 6-17-82

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.3200

N S                     

E W 0.3673



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 11.	+ - 1072.	+ -	+1580. -	+ - 108.	+ - 1140.
THERMAL	+ 404. -	+ - 553.	+ -	+ - 2220.	+ 7216. -	+ 6672. -
SEISMIC-OBE	+ 115. -	+ 96. -	+ -	+ 205690. -	+ 7108. -	+ 7092. -
SRVI	+ 64. - 62.	+ 2278. - 239.	+ -	+ 41405. - 33155.	+ 12312. - 14140.	+ 3764. - 3987.
DESIGN LOAD	+ 583. - 194.	+ 2574. - 1740.	+ -	+ 248765. - 23125.	+ 33656. - 23358.	+ 17528. - 12119.
HYPOTHETICAL LOAD	+ 698. - 309.	+ 2470. - 1836.	+ -	+ 454445. - 43695.	+ 37744. - 32466.	+ 24620. - 19211.

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE
SUBJECT Support Load Summary Sheet <span style="float:right">A</span>		ORIGINATOR <i>R. [unclear]</i>	
MARK NO. <u>Pre-1 [unclear]</u>		DATE <u>6.17.82</u>	
TYPE OF SUPPORT _____		VERIFIER <i>C. [unclear]</i>	
ANALYSIS CODE _____		DATE <u>6.17.82</u>	
		ANALYSIS JOINT NO. <u>252</u>	

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		F <sub>X</sub>	F <sub>Y</sub>	F <sub>Z</sub>	M <sub>X</sub>	M <sub>Y</sub>	M <sub>Z</sub>
DEADWEIGHT	1( ) 2( ) 3( )		-927.			-6372.	
THERMAL	1( ) 2( ) 3( )	-236.	+103.	+31.	+7596.	+15468.	+1020.
SEISMIC - OBE	1( ) 2( ) 3( )		± 214.	± 2424.	± 33024.		
SRVI	1( ) 2( ) 3( )		+372. -331.	+2563. -1048.	+28698. -14447.		
DESIGN LOAD		+ - 236.	+ 689. - 1482.	+ 5018. - 3172.	+ 69318. - 53713.	+ 15468. -	+ 1020. -
HYPOTHETICAL LOAD		+ - 236.	+ 403. - 1696	+ 7442. - 5896.	+ 102342. - 86867.	+ 15468. -	+ 1020. -

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company PROJECT NAME Three Mile Island Unit #1	DEPT. NO. 0432	FILING CODE PAGE
SUBJECT Support Load Summary Sheet <span style="float:right">A</span>		ORIGINATOR R. J. ...	
MARK NO. <u>RC 3-177</u>		DATE <u>5/17/82</u>	
TYPE OF SUPPORT _____		VERIFIER CHOW	
ANALYSIS CODE _____		DATE <u>6/15/82</u>	
		ANALYSIS JOINT NO. <u>H500</u>	

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		F <sub>X</sub>	F <sub>Y</sub>	F <sub>Z</sub>	M <sub>X</sub>	M <sub>Y</sub>	M <sub>Z</sub>
DEADWEIGHT	1 ( )	-3.	-541.	-15.	+4548.	+36.	+144.
	2 ( )						
	3 ( )						
THERMAL	1 ( )	+167.	-245.	-299.	-15896.	+150.	-1111.
	2 ( )						
	3 ( )						
SEISMIC - OBE	1 ( )	±208.	±740.	±194.	±1164.	±2101.	±724.
	2 ( )						
	3 ( )						
SRVZ	1 ( )	+436.	+4019.	+657.	+19241.	+6453.	+17127.
	2 ( )						
	3 ( )	-530.	-1104.	-1155.	-53211.	-2157.	-13972.
DESIGN LOAD		+811.	+4759.	+851.	+34973.	+25977.	+24275.
		-741.	-2652.	-1663.	-58791.	-11481.	-26566.
HYPOTHETICAL LOAD		+1019.	+5499.	+1045.	+46157.	+29651.	+32619.
		-949.	-3362.	-1857.	-69975.	-15105.	-34210.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal ± (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. Clump

MARK NO. PR29

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 302

SEISMIC CATEGORY \_\_\_\_\_

DATE 5/7/82

VERIFIER J. G. ...

DATE 5/8/82



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.3951

N S \_\_\_\_\_

E W \_\_\_\_\_

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 6. -	+ -	+ 8. -	+ -	+ -	+ -
THERMAL	+ - 414.	+ -	+ 405. -	+ -	+ -	+ -
SEISMIC-OBE	+ - 717.	+ -	+ 795. -	+ -	+ -	+ -
SRV2	+ 928. - 907.	+ -	+ 781. - 621.	+ -	+ -	+ -
DESIGN LOAD	+ 1651. - 2032.	+ -	+ 1989. - 1416.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2568. - 2755.	+ -	+ 2784. - 2211.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE




GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR45  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. S303  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
R. C. Jones  
 DATE 1/17/82  
 VERIFIER  
C. H. W.  
 DATE 6/18/82



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.5127  
 N 0.0119  
 E W 0.0382

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ - 395.	+ -	+ -	+ -	+ -
SRVZ	+ -	+ 2308. - 594.	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ 2706. - 992.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ 3104. - 1390.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. C. [unclear]

MARK NO. PR31


ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 304

SEISMIC CATEGORY \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.1427  
 N S \_\_\_\_\_  
 E W \_\_\_\_\_



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -569.	+ -	+ 8. -	+ -	+ -	+ -
THERMAL	+3884. -	+ -	+ -32.	+ -	+ -	+ -
SEISMIC-OBE	+ -3093.	+ -	+ -63.	+ -	+ -	+ -
SRV2	+711. -662.	+ -	+1032. -963.	+ -	+ -	+ -
DESIGN LOAD	+7688. -4324.	+ -	+1103. -1058.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+10721. -7417.	+ -	+1166. -1121.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR20  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 307  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
R. Stone  
 DATE 7-22  
 VERIFIER  
C. Stone  
 DATE 8-12

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 1.2238  
 N S \_\_\_\_\_  
 E W 0.0661



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 565. - 1839.	+ -	+ -	+ -	+ -	+ -
THERMAL	+ 3857. -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ 3067. -	+ -	+ -	+ -	+ -	+ -
SRV2	+ 820. - 1719.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 4452. - 2643. - 1839.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 7519. - 11710. - 1839.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: RCL-2

MARK NO. PR42

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 308

SEISMIC CATEGORY \_\_\_\_\_

DATE: 11-52

VERIFIER: C.M.S.


DATE: 11-52

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.4793

N S 0.2256

E W 0.5289



(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ - 286.	+ -	+ -	+ -
SRV2	+ -	+ -	+ - 1868. - 2286.	+ -	+ -	+ -
DESIGN LOAD	+ -	+ -	+ - 2154. - 2572.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ -	+ - 2440. - 2858.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: *R. C. ...*

MARK NO. PR18

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 311

SEISMIC CATEGORY \_\_\_\_\_

DATE 11/72

VERIFIER C. ...

DATE 6/18/52



PREDICTED PIPE MOVEMENT (INCHES)

UP DN 1.3883

W S 0.6214

E W 0.3673

(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	- 672.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
SRV2	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	- 672.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	- 672.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. C. ...

MARK NO. PK15

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 314

SEISMIC CATEGORY \_\_\_\_\_

DATE 1/17/72

VERIFIER C. ...

DATE 6/1/72

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.7492

N S 0.7857

E W 0.2405



(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ - 900.	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 900.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 900.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PR40  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 317  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR  
 DATE 5-17-82  
 VERIFIER  
C.D.W.  
 DATE 6-18-82

PREDICTED PIPE MOVEMENT (INCHES)  
 (UP/DN) 0.0515  
 (N) S 0.6447  
 (E) W 0.5506



	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 227.	+ -	+ -	+ -	+ -	+ -
SRVZ	+ 3359. - 3263.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 3586. - 3490.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 3813. - 3717.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Cases</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
B & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: A. S. ...

MARK NO. PR12  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 318  
 SEISMIC CATEGORY \_\_\_\_\_

DATE 7/72  
 VERIFIER C. D. ...  
 DATE 6/17/72

PREDICTED PIPE MOVEMENT (INCHES)

UP DN, 0.1963  
 (N) S 0.4015  
 (E) W 0.2975



(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ - 946.	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 946.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 946.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating



STATUS:  PRELIMINARY  FINAL

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. C. ...

MARK NO. PR30

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 319

SEISMIC CATEGORY \_\_\_\_\_

DATE 7-5-

VERIFIER C. NEW

DATE 6-15-72



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.4249

N S 0.1026

E W 0.0518

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ - 1493.	+ -	+ -	+ -	+ -
SRVZ	+ -	+ 2608. - 2627.	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ 4101. - 4120.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ 5594. - 5613.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. PK22


ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 322

SEISMIC CATEGORY \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)

UP  $\overline{DM}$  0.3997  
 N S \_\_\_\_\_  
 E W \_\_\_\_\_



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 39.	+ -	+ - 59.	+ -	+ -	+ -
THERMAL	+ 1765. -	+ -	+ - 900.	+ -	+ -	+ -
SEISMIC-OBE	+ 216. -	+ -	+ 364. -	+ -	+ -	+ -
SRVZ	+ 762. - 786.	+ -	+ 5040. - 3811.	+ -	+ -	+ -
DESIGN LOAD	+ 2743. - 1041.	+ -	+ 5404 - 5134.	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2959. - 1257.	+ -	+ 5768. - 5498.	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. [Signature]

MARK NO. PR27

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 323

SEISMIC CATEGORY \_\_\_\_\_

DATE 7/12

VERIFIER C. [Signature]

DATE 6/12/72



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.1248

N S \_\_\_\_\_

E W \_\_\_\_\_

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 39. -	+	+ 45. -	+	+	+
THERMAL	+ - 7707.	+	+ 2409. -	+	+	+
SEISMIC-OBE	+ - 134.	+	+ 185. -	+	+	+
SKVZ	+ 518. - 527.	+	+ 1233. - 1384.	+	+	+
DESIGN LOAD	+ 691. - 8368.	+	+ 5272. - 1569.	+	+	+
HYPOTHETICAL LOAD	+ 825. - 8502.	+	+ 4057. - 1754.	+	+	+

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

STATUS:  PRELIMINARY  FINAL

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: [Signature]

MARK NO. PK9

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 326

SEISMIC CATEGORY \_\_\_\_\_

DATE 6/17/82

VERIFIER C. L. W.

DATE 6/17/82

PREDICTED PIPE MOVEMENT (INCHES)

UP DN \_\_\_\_\_

(N) S 0.2928

E (W) 0.0055



(ANALYST TO DEFINE)  
NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	-1009.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-565.	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-1847.	-	-	-	-
CRVZ	+	+	+	+	+	+
	-	-3218. -2425.	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	-4565. -5346.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	-5912. -6693.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE
SUBJECT Support Load Summary Sheet <i>A</i>			ORIGINATOR <i>[Signature]</i>
MARK NO. <u>PK7</u>			DATE <u>7-82</u>
TYPE OF SUPPORT _____			VERIFIER <i>[Signature]</i>
ANALYSIS CODE _____			DATE <u>6-1-82</u>
ANALYSIS JOINT NO. <u>3-9</u>			

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
DEADWEIGHT	1( ) 2( ) 3( )	-5.	-588.	+21.	+624.	+828.	+4428.
THERMAL	1( ) 2( ) 3( )	+5204.	-1210.	-881.	+2204.	-74782.	-111452.
SEISMIC - OBE	1( ) 2( ) 3( )	±346.	±567.	±1138.	±17724.	±74322.	±16562.
SRVZ	1( ) 2( ) 3( )	+3008.	+180.	+192.	+6160.	+8251.	+9607.
		-1209.	-177.	-90.	-6432.	-16232.	-7724.
DESIGN LOAD		+8558. -1560.	+547. -2342.	+1351. -2309.	+27712. -24156.	+83407. -185342.	+30462. -132952.
HYPOTHETICAL LOAD		+8904. -1906.	+914. -2709.	+2489. -3447.	+45436. -41880.	+157725. -259676.	+46231. -150220.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. PREA

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. S332


SEISMIC CATEGORY \_\_\_\_\_

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.1990 (F)

N S

E W 0.0154 (E)



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

NON-GLOBAL

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ 88. -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ 2248. -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ 578. -	+ -	+ -	+ -	+ -	+ -
SRV2	+ 1814. - 1094.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 4528. - 1472.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 4906. - 1850.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

STATUS:  PRELIMINARY  FINAL

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R. C. [unclear]

MARK NO. PR51

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 333

SEISMIC CATEGORY \_\_\_\_\_

DATE 11-12

VERIFIER C. B. W.

DATE 6-18-52



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.0693 (I)

N S \_\_\_\_\_

E W 0.1231 (E)

NON-GLOBAL

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 7.	+ -	+ -	+ -	+ -	+ -
THERMAL	+ - 966.	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 881.	+ -	+ -	+ -	+ -	+ -
SRV2	+ 796. - 807.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 1677. - 2663.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2558. - 3544.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. PR3

ANALYSIS CODE \_\_\_\_\_


ANALYSIS JOINT NO. 336

SEISMIC CATEGORY \_\_\_\_\_

DATE 6-12-72

VERIFIER C. J. ...

DATE 6-15-72



RIGHT HAND CARTESIAN  
COORDINATE SYSTEM  
  
(ANALYST TO DEFINE)  
NORTH

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.1735

N 0.0984

E 0.0553

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+	+	+	+	+	+
	-	- 1045.	-	-	-	-
THERMAL	+	+	+	+	+	+
	-	-	-	-	-	-
SEISMIC-OBE	+	+	+	+	+	+
	-	-	-	-	-	-
DESIGN LOAD	+	+	+	+	+	+
	-	- 1045.	-	-	-	-
HYPOTHETICAL LOAD	+	+	+	+	+	+
	-	- 1045.	-	-	-	-

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: R 21

MARK NO. PK36

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 327

SEISMIC CATEGORY \_\_\_\_\_

DATE 7-12

VERIFIER C.H.W.


DATE 6-18-82

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.5125

N/S 0.3183

E/W 0.0265



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 3002.	+ -	+ -	+ -	+ -	+ -
JRV2	+ 5292. - 1151.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 6294. - 4153.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 9296. - 7155.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: *R. D. ...*

MARK NO. PK25

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 340

SEISMIC CATEGORY \_\_\_\_\_

DATE 7/2/...

VERIFIER C. ...


DATE 6/...

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.7160 (Y)

N S 0.5125 (X)

E W 0.1557 (Z)



*NON-GLOBAL*

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 4767.	+ -	+ -	+ -	+ -	+ -
SRV2	+ 1331. - 977.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 6098. - 5744.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 10865. - 10511.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE


SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK 23  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. S341  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER CB  
 DATE 6-11-72

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 0.9540  
 N/S 0.4434  
 E/W 0.1473



RIGHT HAND CARTESIAN  
 COORDINATE SYSTEM  
 (ANALYST TO DEFINE)  
 NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ - 1156.	+ -	+ -	+ -	+ -
SRV2	+ -	+ 2422. - 491.	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ 3578. - 1647.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ 4734. - 2803.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports


Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

MARK NO. PK2  
 ANALYSIS CODE \_\_\_\_\_  
 ANALYSIS JOINT NO. 344  
 SEISMIC CATEGORY \_\_\_\_\_

ORIGINATOR \_\_\_\_\_  
 DATE \_\_\_\_\_  
 VERIFIER \_\_\_\_\_  
 DATE \_\_\_\_\_



RIGHT HAND CARTESIAN  
 COORDINATE SYSTEM  
 (ANALYST TO DEFINE)  
 NORTH

PREDICTED PIPE MOVEMENT (INCHES)  
 (UP) DN 1.0372  
 N (S) 0.3633  
 (E) W 0.1545

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ - 1115.	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ -	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ -	+ - 1115.	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ -	+ - 1115.	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1 & 2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. PR54

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 5345

SEISMIC CATEGORY \_\_\_\_\_

DATE 7-82

VERIFIER C. D. W.


DATE 6-82

PREDICTED PIPE MOVEMENT (INCHES)

UP DN 0.9969

N 0.1824

E W 0.2582



(ANALYST TO DEFINE)  
NORTH

*NON-GLOBAL*

	DESIGN MECHANICAL LOADS					
	FORCE ( LBS. )			MOMENT ( IN.-LBS. )		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ -	+ -	+ -	+ -	+ -	+ -
THERMAL	+ -	+ -	+ -	+ -	+ -	+ -
SEISMIC-OBE	+ - 1097.	+ -	+ -	+ -	+ -	+ -
SRV2	+ 708. - 3316.	+ -	+ -	+ -	+ -	+ -
DESIGN LOAD	+ 1805. - 4413.	+ -	+ -	+ -	+ -	+ -
HYPOTHETICAL LOAD	+ 2902. - 5510.	+ -	+ -	+ -	+ -	+ -

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2)OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.C. NUMBER 04-5064-000	PAGE

SUBJECT: SUPPORT LOAD SUMMARY SHEET

ORIGINATOR: \_\_\_\_\_

MARK NO. PR32

ANALYSIS CODE \_\_\_\_\_

ANALYSIS JOINT NO. 348

SEISMIC CATEGORY \_\_\_\_\_

DATE 1/17/82

VERIFIER G. W. W.


DATE 6/17/82

PREDICTED PIPE MOVEMENT (INCHES)

UP/DN 1.32

N S \_\_\_\_\_

E W 0.3360



RIGHT HAND CARTESIAN COORDINATE SYSTEM

(ANALYST TO DEFINE) NORTH

	DESIGN MECHANICAL LOADS					
	FORCE (LBS.)			MOMENT (IN.-LBS.)		
	Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	+ - 17.	+ - 1125.	+ -	+ 1440. -	+ - 444.	+ - 2364.
THERMAL	+ - 221.	+ - 396.	+ -	+ - 8868.	+ - 11136.	+ 12360. -
SEISMIC-OBE	+ 1542. -	+ 455. -	+ -	+ 341532. -	+ 36624. -	+ 41124. -
CRVZ	+ 322. - 305.	+ 2476. - 298.	+ -	+ 22632. - 23520.	+ 4423. - 3697.	+ 10596. - 11256.
DESIGN LOAD	+ 1864. - 2085.	+ 2931. - 2274.	+ -	+ 565604. - 373900.	+ 41047. - 51901.	+ 64320. - 54744.
HYPOTHETICAL LOAD	+ 3406. - 3627.	+ 3386. - 2729.	+ -	+ 707136. - 715422.	+ 77671. - 28525.	+ 105504. - 95868.

Design loading combinations for seismic category 1, 2, 3 and non-nuclear supports

Seismic Category	Loading Cases	Condition Classification
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	Metropolitan Edison Company	DEPT. NO. 0432	FILING CODE
	PROJECT NAME Three Mile Island Unit #1	W.O. NUMBER 04-5064-000	PAGE
SUBJECT Support Load Summary Sheet <i>A</i>		ORIGINATOR <i>R. D. ...</i>	
MARK NO. <i>Press. No. - 16</i>		DATE <i>5-17-72</i>	
TYPE OF SUPPORT _____		VERIFIER <i>C. ...</i>	
ANALYSIS CODE _____		DATE <i>5-17-72</i>	
		ANALYSIS JOINT NO. <i>356</i>	

LOAD TYPE	BRANCH JOINT NO.	SUPPORT LOAD (LBS.) (IN.-LBS.)					
		Fx	Fy	Fz	Mx	My	Mz
DEADWEIGHT	1( ) 2( ) 3( )	+4.	-898.	+1.	-3648.	-166.	-504.
THERMAL	1( ) 2( ) 3( )	+312.	+199.	+134.	+12912.	-15072.	-4224.
SEISMIC - OBE	1( ) 2( ) 3( )	±500.	±506.	±4553.	±87228.	±5064.	±10372.
<i>SRV2</i>	1( ) 2( ) 3( )	+696. -804.	+339. -374.	+1233. -1270.	+18960. -20844.	+3060. -2416.	+15288. -13212.
DESIGN LOAD		+1512. -1304.	+1044. -1778.	+5921. -5823.	+119100. -111720.	+8124. -22720.	+25620. -28332.
HYPOTHETICAL LOAD		+2012. -1804.	+1550. -2284.	+10474. -10376.	+206328. -198948.	+13188. -27784.	+35952. -38664.

Design loading combinations for seismic category 1, 2, 3, and non-nuclear supports

<u>Seismic Category</u>	<u>Loading Case</u>	<u>Condition Classification</u>
1&2	a) Deadweight + Thermal	(Normal) Operating
	b) Deadweight + Thermal + OBE	(Occasional) Design
	c) Deadweight + Thermal + (2) OBE	(Occasional) Hypothetical
3 & Non-Nuclear	a) Deadweight + Thermal	(Normal) Operating

FILING CODE



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT		CISID		PAGE
REV.	0	1	2	3
MICROFILMED				PAGES
ORIGINATOR	L. K. ...			
DATE	7/20/82			

10.2. SUPPORT LOAD SUMMARY

11. REFERENCE

1. Dresser Valve N-100 Cataloge, "Consolidated and Hancock Valves for Nuclear Service".
2. Safety and Relief Valve Test Report, EPRI, April 1, 1981.
3. TPIPE 4.2 User Manual, June 1982.
4. Seismic Design Criteria, October 9, 1969.
5. Valve Selection/Justification Report, April 1, 1982.
6. "Guide for Application of Valve Test Program Results to Plant Specific Evaluation", Rev. 1, April 5, 1982.